

No.	LOCATION (BIÑAN CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
	Sampling Point	Barangay					
1	Adelina Deepwell	Brgy. Sto. Tomas, Biñan	12/8/2015	2:20 PM	<1	ABSENT	0.40
2	Gate Entrance, Adelina	Brgy. Sto. Tomas, Biñan	12/8/2015	2:25 PM	-	ABSENT	0.33
3	Source, Almeda	Brgy. Dela Paz, Biñan	12/2/2015	10:44 AM	<1	ABSENT	<0.30
4	Brgy. Hall	Brgy. Dela Paz, Biñan	12/2/2015	11:05 AM	-	ABSENT	<0.30
5	Source, Malaban Faraon	Brgy. San Antonio, Biñan	12/2/2015	9:41 AM	<1	ABSENT	<0.30
6	Block 5 Lot 12, Margarita Homes	Brgy. San Antonio, Biñan	12/2/2015	9:21 AM	-	ABSENT	<0.30
7	Source, Southville Langkiwa	Brgy. Langkiwa, Biñan	12/7/2015	1:14 PM	<1	ABSENT	<0.30
8	Block 40, Phase 20, Southville Langkiwa	Brgy. Langkiwa, Biñan	12/7/2015	1:25 PM	-	ABSENT	<0.30
9	Tank, Metroville	Brgy. Canlalay, Biñan	12/2/2015	12:04 PM	<1	ABSENT	<0.30
10	Clubhouse, Metroville	Brgy. Halang, Biñan	12/2/2015	12:12 PM	-	ABSENT	<0.30
11	Source, Phase 1B Olivarez Subdivision	Brgy. Sto. Tomas, Biñan	12/8/2015	3:10 PM	<1	ABSENT	<0.30
12	Block 1 Lot 26, Olivarez Phase 3	Brgy. Sto. Tomas, Biñan	12/8/2015	2:58 PM	-	ABSENT	0.74
13	Block 1 Lot 16, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	12/8/2015	2:37 PM	<1	ABSENT	0.77
14	Block 2 Lot 9, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	12/8/2015	2:45 PM	-	ABSENT	0.73
15	Brgy. Hall - Poblacion	Brgy. Poblacion, Biñan	12/2/2015	10:26 AM	<1	ABSENT	0.34
16	#84A, Bonifacio St.	Brgy. Canlalay, Biñan	12/2/2015	11:22 AM	-	ABSENT	<0.30
17	Golden City Canlalay - Clubhouse	Brgy. Canlalay, Biñan	12/2/2015	11:36 AM	-	ABSENT	<0.30
18	Tangub St., Pragmatic	Brgy. Sto. Tomas, Biñan	12/8/2015	12:30 PM	<1	ABSENT	<0.30
19	Bais St., Pragmatic	Brgy. Sto. Tomas, Biñan	12/8/2015	12:45 PM	-	ABSENT	<0.30
20	#407, San Vicente	Brgy. San Vicente, Biñan	12/8/2015	2:03 PM	<1	ABSENT	0.32
21	B12 L5, Bayabas St. Olivarez 7	Brgy. San Vicente, Biñan	12/8/2015	1:52 PM	-	ABSENT	<0.30
22	#21, Soro-Soro	Brgy. Soro-soro, Biñan	12/2/2015	12:43 PM	<1	ABSENT	0.73
23	#76, Soro-Soro	Brgy. Soro-soro, Biñan	12/2/2015	12:30 PM	-	ABSENT	0.72
24	South Plains II Deepwell	Brgy. Sto. Tomas, Biñan	12/8/2015	11:40 AM	<1	ABSENT	1.36
25	Block 11 Lot 6, South Plains II	Brgy. Sto. Tomas, Biñan	12/8/2015	11:51 AM	-	ABSENT	1.33
26	Town & Country Amsterdam Deepwell	Brgy. Sto. Tomas, Biñan	12/8/2015	3:24 PM	<1	ABSENT	0.51
27	Town & Country Block 35 Lot 21-Amsterdam	Brgy. Sto. Tomas, Biñan	12/8/2015	3:30 PM	-	ABSENT	0.50
28	Town & Country Pennsylvania Deepwell	Brgy. Sto. Tomas, Biñan	12/7/2015	2:02 PM	<1	ABSENT	0.77
29	Town & Country Block 2 Lot 5	Brgy. Sto. Tomas, Biñan	12/7/2015	1:51 PM	-	ABSENT	0.76
30	Source 1, Verdana Subdivision	Brgy. Mamlasan, Biñan	12/7/2015	12:33 PM	<1	ABSENT	<0.30
31	Block 5, Lot 16	Brgy. Malamig, Biñan	12/7/2015	1:00 PM	-	ABSENT	<0.30
32	Verdana Clubhouse	Brgy. Mamlasan, Biñan	12/7/2015	12:47 PM	-	ABSENT	<0.30
33	Drinking Fountain, Canlalay Elementary School	Brgy. Canlalay, Biñan	12/2/2015	11:48 AM	-	ABSENT	<0.30
34	Drinking Fountain, Dela Paz Elementary School	Brgy. Dela Paz, Biñan	12/8/2015	3:00 PM	<1	ABSENT	<0.30
35	Drinking Fountain, Ganado Elementary School	Brgy. Mamlasan, Biñan	12/8/2015	10:59 AM	-	ABSENT	<0.30
36	Drinking Fountain, Loma Elementary School	Brgy. Malamig, Biñan	12/7/2015	12:14 PM	-	ABSENT	<0.30
37	Drinking Fountain 1, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	12/2/2015	10:02 AM	-	ABSENT	<0.30
38	Drinking Fountain 2, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	12/2/2015	10:09 AM	-	ABSENT	<0.30
39	Drinking Fountain, St. Michael School of Biñan	Brgy. Platero, Biñan	12/2/2015	8:50 AM	<1	ABSENT	0.64
40	Sea-oil	Brgy. Platero, Biñan	12/2/2015	9:01 AM	-	ABSENT	<0.30
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:



**CYBIL A. ERICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

Certified Correct:



**AMPARO C. CAÑAMO**  
Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY  
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION  
(DECEMBER 2015)

LOCATION (SANTA ROSA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
#	Sampling Point	Barangay					
1	Alinsod Deepwell	Brgy. Poooc, Sta. Rosa	12/9/2015	1:56 PM	<1	ABSENT	<0.30
2	#152, Purok 1, Alinsod	Brgy. Poooc, Sta. Rosa	12/9/2015	2:08 PM	-	ABSENT	0.74
3	Source, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	12/8/2015	9:42 AM	<1	ABSENT	<0.30
4	Block 1 Lot 9, Phase 1, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	12/8/2015	9:58 AM	-	ABSENT	<0.30
5	Source, Bayshore 2	Brgy. Sinalhan, Sta. Rosa	12/8/2015	10:26 AM	<1	ABSENT	<0.30
6	Block 8 Lot 6 Phase 3, Bayshore 2	Brgy. Sinalhan, Sta. Rosa	12/8/2015	10:11 AM	-	ABSENT	<0.30
7	Cobassuise Deepwell	Brgy. Malitlit, Sta. Rosa	12/8/2015	1:05 PM	<1	ABSENT	1.16
8	Cobassuise Block 5 Lot 25	Brgy. Malitlit, Sta. Rosa	12/8/2015	1:09 PM	-	ABSENT	1.28
9	Golden City Ph 1E/3E Deepwell	Brgy. Dila, Sta. Rosa	12/21/2015	11:56 AM	<1	ABSENT	<0.30
10	Golden City Ph 1E/3E Block 6 Lot 6	Brgy. Dila, Sta. Rosa	12/21/2015	12:08 PM	-	ABSENT	<0.30
11	Golden City Ph 2E Deepwell	Brgy. Dila, Sta. Rosa	12/21/2015	11:25 AM	<1	ABSENT	0.44
12	Golden City Ph 2E Block 13 Lot 5	Brgy. Dila, Sta. Rosa	12/21/2015	11:40 AM	-	ABSENT	<0.30
13	Laguna Bel-Air 1 Block 7 Deepwell	Brgy. Don Jose, Sta. Rosa	12/14/2015	12:54 PM	<1	ABSENT	0.74
14	Laguna Bel-Air 1 Block 7 Lot 74	Brgy. Don Jose, Sta. Rosa	12/14/2015	1:02 PM	-	ABSENT	0.78
15	Laguna Bel-Air 1 Block 34 Deepwell	Brgy. Don Jose, Sta. Rosa	12/1/2015	2:57 PM	<1	ABSENT	0.66
16	Laguna Bel-Air 1 Block 34 Lot 59	Brgy. Don Jose, Sta. Rosa	12/1/2015	2:50 PM	-	ABSENT	0.66
17	Laguna Bel-Air 2 Block 71 Deepwell	Brgy. Don Jose, Sta. Rosa	12/1/2015	3:15 PM	<1	ABSENT	<0.30
18	Laguna Bel-Air 2 Block 71 Lot 4	Brgy. Don Jose, Sta. Rosa	12/1/2015	3:10 PM	-	ABSENT	<0.30
19	Laguna Bel-Air 2 Block 108 Deepwell	Brgy. Don Jose, Sta. Rosa	12/14/2015	1:39 PM	<1	ABSENT	<0.30
20	Laguna Bel-Air 2 Block 108 - Church	Brgy. Don Jose, Sta. Rosa	12/14/2015	1:49 PM	-	ABSENT	<0.30
21	Laguna Bel-Air 3 Block 2 Deepwell	Brgy. Loma, Sta. Rosa	12/1/2015	1:54 PM	<1	ABSENT	<0.30
22	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	Brgy. Loma, Sta. Rosa	12/1/2015	2:02 PM	-	ABSENT	<0.30
23	Laguna Bel-Air 3 Block 8	Brgy. Loma, Sta. Rosa	12/1/2015	2:32 PM	<1	ABSENT	<0.30
24	Laguna Bel-Air 3 Block 8 Brenna Model House	Brgy. Loma, Sta. Rosa	12/1/2015	2:40 PM	-	ABSENT	<0.30
25	Laguna Bel-Air 3 Block 50 Deepwell	Brgy. Loma, Sta. Rosa	12/1/2015	2:12 PM	<1	ABSENT	<0.30
26	Laguna Bel-Air 3 - Clubhouse	Brgy. Loma, Sta. Rosa	12/1/2015	2:22 PM	-	ABSENT	<0.30
27	Laguna Bel-Air 4 Block 43 Deepwell	Brgy. Don Jose, Sta. Rosa	12/14/2015	1:13 PM	<1	ABSENT	1.73
28	Laguna Bel-Air 4 Block 47 Lot 12	Brgy. Don Jose, Sta. Rosa	12/14/2015	1:23 PM	-	ABSENT	1.51
29	Source, Market Area	Brgy. Balibago, Sta. Rosa	12/8/2015	10:42 AM	<1	ABSENT	<0.30
30	Block 9 Lot 2, Terry Town West, Market Area	Brgy. Balibago, Sta. Rosa	12/8/2015	8:40 AM	-	ABSENT	<0.30
31	Metrogate, Tank	Brgy. Tagapo, Sta. Rosa	12/8/2015	11:48 AM	<1	ABSENT	1.27
32	Rosa Subd., Metrogate	Brgy. Macablang, Sta. Rosa	12/8/2015	11:58 AM	-	ABSENT	2.35
33	Source, New Santa Rosa Homes (near DW)	Brgy. Dita, Sta. Rosa	12/21/2015	10:40 AM	<1	ABSENT	0.81
34	Block 19 Lot 11, New Santa Rosa Homes	Brgy. Dita, Sta. Rosa	12/21/2015	10:51 AM	-	ABSENT	0.85
35	Source, Pulong Santa Cruz	Brgy. Pulong Sta. Cruz, Sta. Rosa	12/1/2015	11:18 AM	<1	ABSENT	0.93
36	Purok 5, Sitio Arattan	Brgy. Pulong Sta. Cruz, Sta. Rosa	12/1/2015	1:28 PM	-	ABSENT	0.90
37	Source, Rosewood	Brgy. Halang, Sta. Rosa	12/14/2015	12:14 PM	<1	ABSENT	0.97
38	Block 7 Lot 26, Rosewood	Brgy. Halang, Sta. Rosa	12/14/2015	12:24 PM	-	ABSENT	0.83
39	San Lorenzo Royale Deepwell	Brgy. Dita, Sta. Rosa	12/1/2015	11:53 AM	<1	ABSENT	<0.30
40	Block 11 Lot 52, San Lorenzo Royale	Brgy. Dita, Sta. Rosa	12/1/2015	12:01 PM	-	ABSENT	<0.30
41	Purok 2 near Deepwell, Sinalhan	Brgy. Sinalhan, Sta. Rosa	12/8/2015	9:08 AM	<1	ABSENT	<0.30
42	Purok 4, Sinalhan	Brgy. Sinalhan, Sta. Rosa	12/8/2015	9:26 AM	-	ABSENT	<0.30
43	Sol-Car Deepwell	Brgy. Dita, Sta. Rosa	12/9/2015	1:02 PM	<1	ABSENT	1.11
44	Front Gate, Sol-Car	Brgy. Dita, Sta. Rosa	12/9/2015	1:12 PM	-	ABSENT	1.11
45	Deepwell 1, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	12/1/2015	11:20 AM	<1	ABSENT	0.53
46	Clubhouse, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	12/1/2015	11:38 AM	-	ABSENT	<0.30
47	Deepwell 6, Phase 4C, San Jose Village I	Brgy. Don Jose, Sta. Rosa	12/1/2015	10:38 AM	<1	ABSENT	<0.30
48	Deepwell 2, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	12/1/2015	11:01 AM	<1	ABSENT	2.58
49	Clubhouse, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	12/1/2015	11:09 AM	-	ABSENT	<0.30
50	Clubhouse, San Jose Village I - Phase 4C	Brgy. Don Jose, Sta. Rosa	12/1/2015	10:50 AM	-	ABSENT	<0.30
51	Deepwell 11, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	12/1/2015	10:11 AM	<1	ABSENT	<0.30
52	Clubhouse, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	12/1/2015	10:21 AM	-	ABSENT	<0.30
53	Deepwell 7, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	12/1/2015	9:31 AM	<1	ABSENT	0.64
54	Clubhouse, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	12/1/2015	9:41 AM	-	ABSENT	0.60
55	Booster Tank, Santa Rosa Estates	Brgy. Don Jose, Sta. Rosa	12/1/2015	12:12 PM	<1	ABSENT	<0.30
56	Clubhouse, Santa Rosa Village II	Brgy. Don Jose, Sta. Rosa	12/1/2015	11:54 AM	-	ABSENT	0.72
57	Clubhouse, Santa Rosa Estates I	Brgy. Don Jose, Sta. Rosa	12/1/2015	12:20 PM	-	ABSENT	0.71
58	Clubhouse, Santa Rosa Estates II	Brgy. Don Jose, Sta. Rosa	12/1/2015	12:39 PM	-	ABSENT	0.75
59	Southville Caingin Phase 1, Block 52 Lot 23	Brgy. Caingin, Sta. Rosa	12/14/2015	11:01 AM	<1	ABSENT	<0.30
60	Southville Caingin Phase 1, Block 57 Lot 17	Brgy. Caingin, Sta. Rosa	12/14/2015	11:10 AM	-	ABSENT	<0.30

61	Southville Caingin Phase 5, Block 1 Lot 34	Brgy. Pooc, Sta. Rosa	12/14/2015	10:34 AM	<1	ABSENT	<0.30
62	Southville Caingin Phase 2, Block 46 Lot 2	Brgy. Pooc, Sta. Rosa	12/14/2015	10:44 AM	-	ABSENT	<0.30
63	Tank, South Hampton	Brgy. Balibago, Sta. Rosa	12/21/2015	12:32 PM	<1	ABSENT	0.57
64	Clubhouse, South Hampton	Brgy. Balibago, Sta. Rosa	12/21/2015	12:42 PM	-	ABSENT	0.33
65	Terra Fortuna Deepwell	Brgy. Malitlit, Sta. Rosa	12/8/2015	9:50 AM	<1	ABSENT	1.28
66	Block 11 Lot 16, Terra Fortuna	Brgy. Malitlit, Sta. Rosa	12/8/2015	10:01 AM	-	ABSENT	0.47
67	Villa Esmeralda Deepwell	Brgy. Dita, Sta. Rosa	12/1/2015	12:27 PM	<1	ABSENT	1.14
68	Villa Esmeralda Block (Alabaster St.)	Brgy. Dita, Sta. Rosa	12/1/2015	12:15 PM	-	ABSENT	0.64
69	Villa Las Casas Deepwell	Brgy. Malitlit, Sta. Rosa	12/8/2015	12:39 PM	<1	ABSENT	0.94
70	Villa Las Casas Block 1 Lot 14	Brgy. Malitlit, Sta. Rosa	12/8/2015	12:53 PM	-	ABSENT	6.07
71	Reservoir, Mesaland	Brgy. Don Jose, Sta. Rosa	12/30/2015	10:10 AM	<1	ABSENT	1.50
72	Block 6 Lot 8 Buklod Diwa	Brgy. Pulong Sta. Cruz, Sta. Rosa	12/30/2015	10:30 AM	<1	ABSENT	1.49
73	Brgy. Hall - Malusak	Brgy. Malusak, Sta. Rosa	12/8/2015	11:22 AM	-	ABSENT	0.61
74	Block 11 Lot 2, JB Village	Brgy. Balibago, Sta. Rosa	12/8/2015	12:23 PM	-	ABSENT	1.07
75	#1780	Brgy. Dita, Sta. Rosa	12/9/2015	1:24 PM	-	ABSENT	0.81
76	#31 J. P. Rizal Blvd.	Brgy. Tagapo, Sta. Rosa	12/14/2015	12:05 PM	-	ABSENT	<0.30
77	Laguna AAWater Corporation	Brgy. Balibago, Sta. Rosa	12/29/2015	2:30 PM	-	ABSENT	0.69
78	Drinking Fountain, Caingin Elementary School	Brgy. Caingin, Sta. Rosa	12/14/2015	11:24 AM	-	ABSENT	<0.30
79	Drinking Fountain, Dila Elementary School	Brgy. Dila, Sta. Rosa	12/9/2015	1:37 PM	-	ABSENT	<0.30
80	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	Brgy. Malusak, Sta. Rosa	12/14/2015	11:11 AM	-	ABSENT	0.63
81	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	Brgy. Malusak, Sta. Rosa	12/14/2015	11:06 AM	-	ABSENT	0.59
82	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	Brgy. Tagapo, Sta. Rosa	12/14/2015	10:58 AM	-	ABSENT	0.59
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method


Legend: \*Detection Limit = <0.3 mg/L

Prepared by:



**CYRIL A. ERICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

Certified Correct:



**AMPARO C. CAÑAMO**  
Head of the Laboratory

**LAGUNA AA WATER CORPORATION**

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887

#	LOCATION (CABUYAO CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
	Sampling Point	Barangay					
1	Cabuyao Central Deepwell	Brgy. Pulo, Cabuyao	12/15/2015	12:48 PM	<1	ABSENT	1.12
2	Cabuyao Central Clubhouse	Brgy. Pulo, Cabuyao	12/15/2015	1:06 PM	-	ABSENT	<0.30
3	Block 3 Lot 17, Celestine Phase 1	Brgy. Marinig, Cabuyao	12/15/2015	12:45 PM	<1	ABSENT	2.57
4	Block 26 Lot 4, Celestine Phase 1	Brgy. Marinig, Cabuyao	12/15/2015	1:36 PM	-	ABSENT	<0.30
5	Source, Celestine Phase 2	Brgy. Marinig, Cabuyao	12/15/2015	1:20 PM	<1	ABSENT	<0.30
6	Celestine Phase 2 Block 11 Lot 19	Brgy. Marinig, Cabuyao	12/15/2015	1:06 PM	-	ABSENT	<0.30
7	Celestine Ville Deepwell	Brgy. Gulod, Cabuyao	12/2/2015	8:39 AM	<1	ABSENT	<0.30
8	Guardhouse, Celestine Ville	Brgy. Gulod, Cabuyao	12/2/2015	8:55 AM	-	ABSENT	<0.30
9	Mabuhay Phase 1 Block 101 Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	9:46 AM	<1	ABSENT	0.84
10	Mabuhay Phase 1 Block 95 Lot 57	Brgy. Mamatid, Cabuyao	12/2/2015	9:35 AM	-	ABSENT	0.70
11	Mabuhay Phase 2 Block 141 Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	9:12 AM	<1	ABSENT	<0.30
12	Mabuhay Phase 2 Block 4 Lot 20	Brgy. Mamatid, Cabuyao	12/2/2015	9:20 AM	-	ABSENT	<0.30
13	Mabuhay Phase 2 Block 198 Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	10:12 AM	<1	ABSENT	<0.30
14	Mabuhay Phase 2 Block 222 Lot 20	Brgy. Mamatid, Cabuyao	12/2/2015	10:00 AM	-	ABSENT	<0.30
15	Mabuhay Phase 3 Cluster Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	11:16 AM	<1	ABSENT	<0.30
16	Mabuhay Phase 3 Cluster Block 1 Lot 17	Brgy. Mamatid, Cabuyao	12/2/2015	11:03 AM	-	ABSENT	<0.30
17	Mabuhay Phase 3 Luxury Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	10:29 AM	<1	ABSENT	<0.30
18	Mabuhay Phase 3 Luxury Block 19 Lot 13	Brgy. Mamatid, Cabuyao	12/2/2015	10:46 AM	-	ABSENT	<0.30
19	Mabuhay Phase 5 Deepwell	Brgy. Mamatid, Cabuyao	12/2/2015	11:34 AM	<1	ABSENT	<0.30
20	Mabuhay Phase 5 Block 31 Lot 134	Brgy. Mamatid, Cabuyao	12/2/2015	11:42 AM	-	ABSENT	<0.30
21	Source, Multi-Land III	Brgy. Sala, Cabuyao	12/9/2015	12:04 PM	<1	ABSENT	<0.30
22	Guardhouse, Multi-Land III	Brgy. Sala, Cabuyao	12/9/2015	12:19 PM	-	ABSENT	<0.30
23	Multi-Land IV Deepwell	Brgy. San Isidro, Cabuyao	12/2/2015	11:59 AM	<1	ABSENT	<0.30
24	Multi-Land IV Block 3 Lot 33	Brgy. San Isidro, Cabuyao	12/2/2015	12:06 PM	-	ABSENT	<0.30
25	Source, Niugan	Brgy. Niugan, Cabuyao	12/15/2015	12:10 PM	<1	ABSENT	<0.30
26	Patricia's Apartment, Niugan	Brgy. Niugan, Cabuyao	12/15/2015	12:16 PM	-	ABSENT	<0.30
27	Southville Tank 1 Blk 25 Deepwell	Brgy. Marinig, Cabuyao	12/15/2015	1:56 PM	<1	ABSENT	<0.30
28	Southville Tank 1 Blk 19 Lot 33	Brgy. Marinig, Cabuyao	12/15/2015	2:12 PM	-	ABSENT	<0.30
29	Southville Tank 4 Blk 45 Deepwell	Brgy. Niugan, Cabuyao	12/15/2015	2:17 PM	<1	ABSENT	<0.30
30	Southville Tank 4 Blk 40 Lot 132	Brgy. Niugan, Cabuyao	12/15/2015	2:26 PM	-	ABSENT	<0.30
31	Southville Tank 5 Blk 54 Deepwell	Brgy. Niugan, Cabuyao	12/15/2015	2:24 PM	<1	ABSENT	<0.30
32	Southville Tank 5 Blk 47 Lot 101	Brgy. Niugan, Cabuyao	12/15/2015	2:48 PM	-	ABSENT	<0.30
33	Willow Park, Tank	Brgy. Pulo, Cabuyao	12/15/2015	1:28 PM	<1	ABSENT	<0.30
34	Guardhouse, Willow Park	Brgy. Pulo, Cabuyao	12/15/2015	1:43 PM	-	ABSENT	<0.30
35	Matang Tubig Spring	Brgy. Casile, Cabuyao	12/30/2015	10:00 AM	<1	ABSENT	1.50
36	#253 Elsol Subdivision, Cabuyao City	Brgy. Elsol, Cabuyao	12/9/2015	12:47 PM	-	ABSENT	1.05
37	Wash Area, Niugan Elementary School	Brgy. Niugan, Cabuyao	12/15/2015	12:20 PM	<1	ABSENT	<0.30
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:



**CYRIL A. ERICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

Certified Correct:



**AMPARO C. CAÑAMO**  
Head of the Laboratory

**LAGUNA AAAWATER CORPORATION LABORATORY**  
**MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION**  
(DECEMBER 2015)


LOCATION (CALAMBA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
#	Sampling Point	Address					
1	Deepwell 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	9:00 AM	<1	ABSENT	0.94
2	Near Tank 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	9:10 AM	-	ABSENT	0.92
3	Blow off 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	9:30 AM	-	ABSENT	0.90
4	Deepwell 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	9:40 AM	<1	ABSENT	0.81
5	Near Tank 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	9:50 AM	-	ABSENT	0.84
6	Blow off 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	12/30/2015	10:00 AM	-	ABSENT	0.82
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L


Prepared by:

Certified Correct:


---

**CYRIL A. ERICA, RMT**  
 Analyst (PRC License No. 0054161)  
 (NRL No. WLMA-14-0274)


---

**AMPARO C. CAÑAMO**  
 Head of the Laboratory



LAGUNA AAAWATER CORPORATION LABORATORY  
 MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION  
 (DECEMBER 2015)

LOCATION (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*		
#	Sampling Point	Address						
1	Deepwell Source (after DMI 65)	San Luis Sports Complex, Sta. Cruz, Laguna		12/30/2015	2:30 PM	<1	ABSENT	0.82
2	Canteen No. 4 in front of the Laguna University Administration Bldg.	San Luis Sports Complex, Sta. Cruz, Laguna		12/30/2015	3:00 PM	-	ABSENT	0.71
PNSDW LIMIT						<500	ABSENT	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:

CYRILA ERICA, RMT  
 Analyst (PRC License No. 0054161)  
 (NRL No. WLMA-14-0274)

Certified Correct:

AMPARO C. CAÑAMO  
 Head of the Laboratory

**LAGUNA AAAWATER CORPORATION**  
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company  
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026  
 Telephone Number: (049) 534 1627 • (02) 519 4887

**LAGUNA AAAWATER CORPORATION LABORATORY**  
**MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION**  
(DECEMBER 2015)


LOCATION (ALAMINOS)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
#	Sampling Point	Address					
1	Source, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	00 AM12:5	<1	ABSENT	0.94
2	Block 5 Lot 14, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	12:02 PM	-	ABSENT	0.92
3	Block 67 Lot 7, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	12:27 PM	-	ABSENT	0.90
4	Block 71 Lot 16, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	12:13 PM	-	ABSENT	0.81
5	Block 56 Lot 6, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	12:42 PM	-	ABSENT	0.84
6	Block 27 Lot 14, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	11:41 AM	-	ABSENT	0.82
7	Block 8 Lot 2, BellaVita Homes	Brgy. San Andres, Alaminos	12/14/2015	11:45 AM	-	ABSENT	0.77
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:



**CYRIL A. ERICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

**AMPARO C. CAÑAMO**  
Head of the Laboratory