

**LAGUNA AAAWATER CORPORATION LABORATORY**  
**MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION**  
(OCTOBER 2015)


LOCATION (BIÑAN CITY)	Date of Sampling	Time of Sampling	Heterotrophic	Coliform	Residual
			Plate Count <sup>1</sup> (CFU/mL)	Bacteria <sup>2</sup>	Chlorine <sup>3</sup> (mg/L)*
1 Adelina Deepwell	10/20/2015	12:39 PM	<1	ABSENT	<0.30
2 Gate Entrance, Adelina	10/20/2015	12:50 PM	-	ABSENT	0.57
3 Source, Almeda	10/13/2015	9:55 AM	<1	ABSENT	<0.30
4 Brgy. Hall, Dela Paz	10/13/2015	10:09 AM	-	ABSENT	<0.30
5 Source, Malaban Faraon	10/13/2015	8:32 AM	<1	ABSENT	<0.30
6 Block 5 Lot 12, Margarita Homes	10/13/2015	8:09 AM	-	ABSENT	<0.30
7 Source, Southville Langkiwa	10/5/2015	1:42 AM	<1	ABSENT	<0.30
8 Block 40, Phase 20, Southville Langkiwa	10/5/2015	11:55 AM	-	ABSENT	0.32
9 Tank, Metroville, Brgy. Canlalay	10/7/2015	10:24 AM	<1	ABSENT	<0.30
10 Clubhouse, Metroville	10/7/2015	10:39 AM	-	ABSENT	<0.30
11 Source, Phase 1B Olivarez Subdivision	10/20/2015	2:21 PM	<1	ABSENT	<0.30
12 Block 1 Lot 26, Olivarez Phase 3	10/20/2015	2:07 PM	-	ABSENT	<0.30
13 Block 1 Lot 16, Olivarez Phase 4	10/20/2015	1:32 PM	<1	ABSENT	<0.30
14 Block 2 Lot 9, Olivarez Phase 4	10/20/2015	1:44 PM	-	ABSENT	<0.30
15 Brgy. Hall Poblacion, Brgy. Poblacion, City of Biñan	10/13/2015	9:35 AM	<1	ABSENT	<0.30
16 #84A, Bonifacio St., Brgy. Canlalay	10/13/2015	10:32 AM	-	ABSENT	<0.30
17 Golden City Canlalay - Clubhouse	10/7/2015	10:04 AM	-	ABSENT	<0.30
18 Tangub St., Pragmatic	10/20/2015	10:59 AM	<1	ABSENT	0.31
19 Bais Street, Pragmatic	10/20/2015	11:11 AM	-	ABSENT	<0.30
20 #407, San Vicente	10/20/2015	12:04 AM	<1	ABSENT	<0.30
21 B12 L5, Bayabas St. Olivarez 7, San Vicente	10/20/2015	11:45 AM	-	ABSENT	<0.30
22 #21, Soro-Soro	10/7/2015	11:39 AM	<1	ABSENT	0.90
23 #76, Soro-Soro	10/7/2015	11:25 AM	-	ABSENT	0.84
24 South Plains II Deepwell	10/20/2015	10:22 AM	<1	ABSENT	0.65
25 Block 11 Lot 6, South Plains II	10/20/2015	10:11 AM	-	ABSENT	0.67
26 Southville Town & Country Amsterdam Deepwell	10/20/2015	2:43 PM	<1	ABSENT	0.32
27 Southville Town & Country Block 35 Lot 21-Amsterdam	10/20/2015	2:35 PM	-	ABSENT	<0.30
28 Southville Town & Country Pennsylvania Deepwell	10/5/2015	10:58 AM	<1	ABSENT	1.13
29 Southville Town & Country Block 2 Lot 5	10/5/2015	12:13 PM	-	ABSENT	1.38
30 Source 1, Verdana Subdivision	10/5/2015	1:04 PM	<1	ABSENT	<0.30
31 Block 5 Lot 16, Brgy. Malamig	10/5/2015	1:42 PM	-	ABSENT	<0.30
32 Verdana Clubhouse	10/5/2015	1:18 PM	-	ABSENT	0.37
33 Drinking Fountain, Dela Paz Elementary School	10/13/2015	10:40 AM	-	ABSENT	<0.30
34 Drinking Fountain, Ganado Elementary School	10/20/2015	9:32 AM	-	ABSENT	1.05
35 Drinking Fountain, Loma Elementary School	10/5/2015	1:20 PM	-	ABSENT	<0.30
36 Drinking Fountain 1, Malaban Faraon Elem. School	10/13/2015	9:04 AM	-	ABSENT	<0.30
37 Drinking Fountain 2, Malaban Faraon Elem. School	10/13/2015	9:14 AM	-	ABSENT	<0.30
38 Drinking Fountain, Southville Langkiwa Elem. School	10/5/2015	12:40 PM	-	ABSENT	0.34
39 Drinking Fountain, St. Michael School of Biñan	10/7/2015	9:22 AM	-	ABSENT	1.26
40 Brgy. Platero	10/7/2015	9:35 AM	-	ABSENT	0.70
<b>PNSDW LIMIT</b>			<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:

  
11/21/2015

**CYBIL A. EPICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)



**AMPARO C. CAÑAMO**  
Head of the Laboratory

LOCATION		Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
(SANTA ROSA CITY)						
1	Alinsod Deepwell	10/28/2015	1:10 PM	<1	ABSENT	1.28
2	#152, Purok 1, Alinsod	10/28/2015	1:30 PM	-	ABSENT	1.04
3	Cobassuise Deepwell	10/20/2015	12:17 PM	<1	ABSENT	0.44
4	Cobassuise Block 5 Lot 25	10/20/2015	12:25 PM	-	ABSENT	0.42
5	Golden City Ph 1E/3E Deepwell	10/12/2015	12:00 PM	<1	ABSENT	<0.30
6	Golden City Ph 1E/3E Block 6 Lot 6	10/12/2015	12:19 PM	-	ABSENT	<0.30
7	Golden City Ph 2E Deepwell	10/12/2015	11:26 AM	<1	ABSENT	<0.30
8	Golden City Ph 2E Block 13 Lot 5	10/12/2015	11:41 AM	-	ABSENT	<0.30
9	Laguna Bel-Air 1 Block 7 Deepwell	10/27/2015	1:35 PM	<1	ABSENT	<0.30
10	Laguna Bel-Air 1 Block 7 Lot 74	10/27/2015	1:50 PM	-	ABSENT	<0.30
11	Laguna Bel-Air 1 Block 34 Deepwell	10/5/2015	12:53 PM	<1	ABSENT	0.75
12	Laguna Bel-Air 1 Block 34 Lot 59	10/5/2015	1:04 PM	-	ABSENT	0.74
13	Laguna Bel-Air 1 Block 62 - Clubhouse	10/27/2015	2:32 PM	-	ABSENT	0.35
14	Laguna Bel-Air 2 Block 71 Deepwell	10/12/2015	1:28 PM	<1	ABSENT	<0.30
15	Laguna Bel-Air 2 Block 71 Lot 4	10/12/2015	1:35 PM	-	ABSENT	<0.30
16	Laguna Bel-Air 2 Block 108 Deepwell	10/27/2015	12:11 AM	<1	ABSENT	0.88
17	Laguna Bel-Air 2 Block 108 - Church	10/27/2015	11:46 AM	-	ABSENT	0.75
18	Laguna Bel-Air 3 Block 2 Deepwell	10/5/2015	12:03 PM	<1	ABSENT	0.41
19	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	10/5/2015	12:14 PM	-	ABSENT	0.42
20	Laguna Bel-Air 3 Block 8	10/5/2015	12:39 PM	<1	ABSENT	<0.30
21	Laguna Bel-Air 3 Block 8 Brenna Model House	10/5/2015	12:25 PM	-	ABSENT	<0.30
22	Laguna Bel-Air 3 Block 50 Deepwell	10/5/2015	11:47 AM	<1	ABSENT	<0.30
23	Laguna Bel-Air 3 - Clubhouse	10/5/2015	11:27 AM	-	ABSENT	<0.30
24	Laguna Bel-Air 4 Block 43 Deepwell	10/27/2015	2:18 PM	<1	ABSENT	0.50
25	Laguna Bel-Air 4 Block 47 Lot 12	10/27/2015	2:06 PM	-	ABSENT	0.31
26	Source, Market Area	10/6/2015	9:02 AM	<1	ABSENT	0.34
27	Block 9 Lot 2, Terry Town West, Market Area	10/6/2015	9:23 AM	-	ABSENT	<0.30
28	Metrogate, Tank	10/20/2015	11:04 AM	<1	ABSENT	1.29
29	Rosa Subd. Brgy. Macablang, Metrogate	10/20/2015	11:14 AM	-	ABSENT	1.15
30	Near Tank, New Santa Rosa Homes (near DW)	10/12/2015	10:42 AM	<1	ABSENT	0.41
31	Block 24 Lot 12, New Santa Rosa Homes	10/12/2015	10:59 AM	-	ABSENT	0.39
32	Source, Brgy. Pulong Santa Cruz	10/12/2015	1:05 PM	<1	ABSENT	0.93
33	Purok 5, Sitio Arattan, Brgy. Pulong Santa Cruz	10/12/2015	1:12 PM	-	ABSENT	0.91
34	Source, Rosewood	10/20/2015	8:13 AM	<1	ABSENT	0.46
35	Block 7 Lot 26, Rosewood	10/20/2015	8:23 AM	-	ABSENT	0.41
36	San Lorenzo Royale Deepwell	10/12/2015	12:25 PM	<1	ABSENT	<0.30
37	Block 11 Lot 52, San Lorenzo Royale	10/12/2015	12:14 PM	-	ABSENT	<0.30
38	Purok 2 near Deepwell, Sinalhan	10/6/2015	8:11 AM	<1	ABSENT	<0.30
39	Purok 4, Sinalhan	10/6/2015	8:30 AM	-	ABSENT	<0.30
40	Sol-Car Deepwell	10/21/2015	10:35 AM	<1	ABSENT	0.52
41	Elevated Tank, Sol-Car	10/21/2015	9:45 AM	-	ABSENT	0.54
42	Deepwell 1, Santa Rosa Village I	10/14/2015	11:10 AM	<1	ABSENT	0.44
43	Clubhouse, Santa Rosa Village I	10/14/2015	11:25 AM	-	ABSENT	<0.30
44	Deepwell 6, Phase 4C, San Jose Village I	10/14/2015	10:16 AM	<1	ABSENT	<0.30
45	Deepwell 2, San Jose Village I - Phase 3B	10/14/2015	10:57 AM	<1	ABSENT	0.38
46	Clubhouse, San Jose Village I - Phase 3B	10/14/2015	10:45 AM	-	ABSENT	0.38
47	Clubhouse, San Jose Village I - Phase 4C	10/14/2015	10:28 AM	-	ABSENT	<0.30
48	Deepwell 11, San Jose Village II - Phase V	10/14/2015	9:56 AM	<1	ABSENT	<0.30
49	Clubhouse, San Jose Village II - Phase V	10/14/2015	9:40 AM	-	ABSENT	<0.30
50	Deepwell 7, San Jose Village III - Phase VI	10/14/2015	9:14 AM	<1	ABSENT	<0.30
51	Clubhouse, San Jose Village III - Phase VI	10/14/2015	9:25 AM	-	ABSENT	<0.30
52	Booster Tank, Santa Rosa Estates	10/14/2015	12:00 PM	<1	ABSENT	<0.30

53	Clubhouse, Santa Rosa Village II	10/14/2015	11:42 AM	-	ABSENT	<0.30
54	Clubhouse, Santa Rosa Estates I	10/14/2015	12:14 PM	-	ABSENT	<0.30
55	Clubhouse, Santa Rosa Estates II	10/14/2015	12:27 PM	-	ABSENT	<0.30
56	Southville Caingin Phase 1, Block 52 Lot 23	10/20/2015	9:36 AM	<1	ABSENT	<0.30
57	Southville Caingin Phase 1, Block 57 Lot 17	10/20/2015	9:48 AM	-	ABSENT	<0.30
58	Southville Caingin Phase 5, Block 1 Lot 34	10/20/2015	10:12 AM	<1	ABSENT	0.71
59	Southville Caingin Phase 2, Block 46 Lot 2	10/20/2015	2:37 PM	-	ABSENT	<0.30
60	Tank, South Hampton	10/12/2015	12:49 AM	<1	ABSENT	<0.30
61	Clubhouse, South Hampton	10/12/2015	1:06 PM	-	ABSENT	<0.30
62	Terra Fortuna Deepwell	10/20/2015	3:11 PM	<1	ABSENT	<0.30
63	Block 11 Lot 16, Terra Fortuna	10/20/2015	3:18 PM	-	ABSENT	<0.30
64	Villa Esmeralda Deepwell	10/12/2015	12:46 PM	<1	ABSENT	<0.30
65	Villa Esmeralda Block (Alabaster St.)	10/12/2015	12:38 PM	-	ABSENT	<0.30
66	Villa Las Casas Deepwell	10/20/2015	11:59 AM	<1	ABSENT	<0.30
67	Villa Las Casas Block 1 Lot 14	10/20/2015	12:06 PM	-	ABSENT	1.29
68	Reservoir, Mesaland	10/28/2015	8:42 AM	<1	ABSENT	1.23
69	Block 6 Lot 8 Buklod Diwa	10/28/2015	9:05 AM	<1	ABSENT	1.14
70	Brgy. Malusak	10/6/2015	10:28 AM	-	ABSENT	0.68
71	Block 11 Lot 2, JB Village, Brgy. Balibago	10/20/2015	11:31 AM	-	ABSENT	1.31
72	#1780, Brgy. Dita	10/21/2015	10:55 AM	-	ABSENT	0.58
73	#31 J. P. Rizal Blvd., Tagapo	10/20/2015	8:37 AM	-	ABSENT	<0.30
74	Laguna AAAWater Corporation	10/27/2015	3:02 PM	-	ABSENT	0.79
75	Drinking Fountain, Caingin Elementary School	10/20/2015	10:35 AM	-	ABSENT	
76	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	10/6/2015	9:05 AM	-	ABSENT	0.73
77	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	10/6/2015	9:46 AM	-	ABSENT	0.74
78	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	10/6/2015	9:55 AM	-	ABSENT	0.78
79	Drinking Fountain, Dila Elementary School	10/21/2015	11:11 AM	-	ABSENT	0.59
<b>PNSDW LIMIT</b>					<b>&lt;500</b>	<b>ABSENT</b>

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:



**CYRIL A. ERICA, RMT**

Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

Certified Correct:



**AMPARO C. CAÑAMO**  
Head of the Laboratory

**LAGUNA AAAWATER CORPORATION**

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026


Telephone Number: (049) 534 1627 · (02) 519 4887


LOCATION (CABUYAO CITY)	Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
1 Cabuyao Central Deepwell	10/7/2015	8:38 AM	<1	ABSENT	<0.30
2 Cabuyao Central Clubhouse	10/7/2015	8:53 AM	-	ABSENT	0.48
3 Block 3 Lot 17, Celestine Phase 1	10/6/2015	10:40 AM	<1	ABSENT	<0.30
4 Block 26 Lot 4, Celestine Phase 1	10/6/2015	1:24 AM	-	ABSENT	<0.30
5 Source, Celestine Phase 2	10/6/2015	11:10 AM	<1	ABSENT	<0.30
6 Celestine Phase 2 Block 11 Lot 19	10/6/2015	10:56 AM	-	ABSENT	<0.30
7 Celestine Ville Deepwell	10/13/2015	9:10 AM	<1	ABSENT	<0.30
8 Guardhouse, Celestine Ville	10/13/2015	9:28 AM	-	ABSENT	<0.30
9 Mabuhay Phase 1 Block 101 Deepwell	10/13/2015	10:35 AM	<1	ABSENT	<0.30
10 Mabuhay Phase 1 Block 95 Lot 57	10/13/2015	10:20 AM	-	ABSENT	<0.30
11 Mabuhay Phase 2 Block 4 Lot 20	10/13/2015	9:56 AM	-	ABSENT	<0.30
12 Mabuhay Phase 2 Block 222 Lot 20	10/13/2015	11:01 AM	-	ABSENT	<0.30
13 Mabuhay Phase 3 Cluster Deepwell	10/21/2015	9:52 AM	<1	ABSENT	<0.30
14 Mabuhay Phase 3 Cluster Block 1 Lot 17	10/21/2015	10:06 AM	-	ABSENT	<0.30
15 Mabuhay Phase 3 Luxury Deepwell	10/21/2015	10:31 AM	<1	ABSENT	<0.30
16 Mabuhay Phase 3 Luxury Block 19 Lot 13	10/21/2015	10:17 AM	-	ABSENT	<0.30
17 Mabuhay Phase 5 Deepwell	10/21/2015	9:23 AM	<1	ABSENT	<0.30
18 Mabuhay Phase 5 Block 31 Lot 134	10/21/2015	9:35 AM	-	ABSENT	<0.30
19 Source, Multi-Land III	10/21/2015	11:01 AM	<1	ABSENT	<0.30
20 Guardhouse, Multi-Land III	10/21/2015	9:27 AM	-	ABSENT	<0.30
21 Multi-Land IV Deepwell	10/21/2015	8:47 AM	<1	ABSENT	<0.30
22 Multi-Land IV Block 3 Lot 33	10/21/2015	8:59 AM	-	ABSENT	<0.30
23 Source, Niugan	10/7/2015	10:39 AM	<1	ABSENT	<0.30
24 Patricia's Apartment, Niugan	10/7/2015	10:07 AM	-	ABSENT	1.19
25 Southville Tank 1 Blk 25 Deepwell	10/6/2015	10:15 AM	<1	ABSENT	<0.30
26 Southville Tank 1 Blk 19 Lot 33	10/6/2015	9:56 AM	-	ABSENT	<0.30
27 Southville Tank 4 Blk 45 Deepwell	10/6/2015	9:08 AM	<1	ABSENT	<0.30
28 Southville Tank 4 Blk 40 Lot 132	10/6/2015	9:33 AM	-	ABSENT	0.40
29 Southville Tank 5 Blk 54 Deepwell	10/7/2015	10:16 AM	<1	ABSENT	<0.30
30 Southville Tank 5 Blk 47 Lot 101	10/7/2015	10:03 AM	-	ABSENT	0.35
31 Willow Park, Tank	10/7/2015	9:16 AM	<1	ABSENT	<0.30
32 Guardhouse, Willow Park	10/7/2015	9:30 AM	-	ABSENT	<0.30
33 Matang Tubig Spring, Brgy. Casile, Cabuyao City	10/28/2015	8:19 AM	<1	ABSENT	1.24
34 #253 Elsol Subdivision, Cabuyao City	10/21/2015	8:59 AM	-	ABSENT	0.50
35 Wash Area, Niugan Elementary School	10/7/2015	10:50 AM	-	ABSENT	<0.30
<b>PNSDW LIMIT</b>			<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method  
Legend: \*Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:

  
**CYRIL A. RICA, RMT**  
Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)

  
**AMPARO C. CAÑAMO**  
Head of the Laboratory

**LAGUNA AAAWATER CORPORATION LABORATORY**  
**MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION**  
**(OCTOBER 2015)**


LOCATION  (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count <sup>1</sup> (CFU/mL)	Coliform Bacteria <sup>2</sup>	Residual Chlorine <sup>3</sup> (mg/L)*
1	Source	10/28/2015	11:30 AM	<1	ABSENT	0.54
2	Canteen	10/28/2015	11:45 AM	-	ABSENT	0.48
<b>PNSDW LIMIT</b>				<b>&lt;500</b>	<b>ABSENT</b>	

Test Methods Used: <sup>1</sup>Pour plate, <sup>2</sup>Chromogenic Substrate, <sup>3</sup>DPD Colorimetric Method

Legend: \*Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:



10/28/2015

**CYRILA A. ERICA, RMT**

Analyst (PRC License No. 0054161)  
(NRL No. WLMA-14-0274)



**AMPARO C. CAÑAMO**

Head of the Laboratory

**LAGUNA AAAWATER CORPORATION**

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887