

LOCATION (BIÑAN CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*	
Sampling Point	Barangay						
1	Adelina Deepwell	Brgy. Sto. Tomas, Biñan	2/15/2016	1:32 PM	<1	ABSENT	0.42
2	Gate Entrance, Adelina	Brgy. Sto. Tomas, Biñan	2/15/2016	1:41 PM	-	ABSENT	1.32
3	Source, Almeda	Brgy. Dela Paz, Biñan	2/9/2016	3:08 PM	<1	ABSENT	<0.30
4	Brgy. Hall	Brgy. Dela Paz, Biñan	2/9/2016	3:27 PM	-	ABSENT	<0.30
5	Source, Malaban Faraon	Brgy. San Antonio, Biñan	2/9/2016	2:34 PM	<1	ABSENT	<0.30
6	Block 5 Lot 12, Margarita Homes	Brgy. San Antonio, Biñan	2/9/2016	1:48 PM	-	ABSENT	<0.30
7	Source, Southville Langkiwa	Brgy. Langkiwa, Biñan	2/17/2016	3:05 PM	<1	ABSENT	0.83
8	Block 40, Phase 20, Southville Langkiwa	Brgy. Langkiwa, Biñan	2/17/2016	3:11 PM	-	ABSENT	0.68
9	Tank, Metroville	Brgy. Canlalay, Biñan	2/4/2016	12:01 PM	<1	ABSENT	0.77
10	Clubhouse, Metroville	Brgy. Halang, Biñan	2/4/2016	12:11 PM	-	ABSENT	0.32
11	Source, Phase 1B Olivarez Subdivision	Brgy. Sto. Tomas, Biñan	2/15/2016	1:12 PM	<1	ABSENT	0.74
12	Block 1 Lot 26, Olivarez Phase 3	Brgy. Sto. Tomas, Biñan	2/15/2016	12:52 PM	-	ABSENT	0.48
13	Block 1 Lot 16, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	2/15/2016	12:26 PM	<1	ABSENT	0.44
14	Block 2 Lot 9, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	2/15/2016	12:37 PM	-	ABSENT	0.44
15	Brgy. Hall - Poblacion	Brgy. Poblacion, Biñan	2/9/2016	2:50 PM	<1	ABSENT	<0.30
16	#84A, Bonifacio St.	Brgy. Canlalay, Biñan	2/9/2016	3:39 PM	-	ABSENT	<0.30
17	Golden City Canlalay - Clubhouse	Brgy. Canlalay, Biñan	2/4/2016	11:27 AM	-	ABSENT	0.55
18	Block 75 Lot 8C Ginggog St., Pragmatic	Brgy. Sto. Tomas, Biñan	2/3/2016	9:46 AM	<1	ABSENT	0.73
19	Bais St., Pragmatic	Brgy. Sto. Tomas, Biñan	2/3/2016	10:01 AM	-	ABSENT	<0.30
20	#407, San Vicente	Brgy. San Vicente, Biñan	2/3/2016	10:54 AM	<1	ABSENT	1.06
21	B12 L5, Bayabas St. Olivarez 7	Brgy. San Vicente, Biñan	2/3/2016	10:27 AM	-	ABSENT	0.94
22	Source, Soro-Soro	Brgy. Soro-soro, Biñan	2/4/2016	12:34 PM	<1	ABSENT	<0.30
23	#76, Soro-Soro	Brgy. Soro-soro, Biñan	2/4/2016	12:30 PM	-	ABSENT	<0.30
24	South Plains II Deepwell	Brgy. Sto. Tomas, Biñan	2/3/2016	9:27 AM	<1	ABSENT	1.81
25	Block 11 Lot 6, South Plains II	Brgy. Sto. Tomas, Biñan	2/3/2016	9:18 AM	-	ABSENT	1.89
26	Town & Country Amsterdam Deepwell	Brgy. Sto. Tomas, Biñan	2/15/2016	12:47 PM	<1	ABSENT	0.50
27	Town & Country Block 35 Lot 21-Amsterdam	Brgy. Sto. Tomas, Biñan	2/15/2016	12:58 PM	-	ABSENT	0.57
28	Town & Country Pennsylvania Deepwell	Brgy. Sto. Tomas, Biñan	2/17/2016	2:35 PM	<1	ABSENT	<0.30
29	Town & Country Block 2 Lot 5	Brgy. Sto. Tomas, Biñan	2/17/2016	2:35 PM	-	ABSENT	<0.30
30	Source 1, Verdana Subdivision	Brgy. Mamlasan, Biñan	2/17/2016	3:35 PM	<1	ABSENT	<0.30
31	Block 5, Lot 16	Brgy. Malamig, Biñan	2/17/2016	4:15 PM	-	ABSENT	<0.30
32	Drinking Fountain, Canlalay Elementary School	Brgy. Canlalay, Biñan	2/4/2016	11:44 AM	-	ABSENT	<0.30
33	Drinking Fountain, Ganado Elementary School	Brgy. Mamlasan, Biñan	2/3/2016	8:29 AM	-	ABSENT	0.61
34	Drinking Fountain, Loma Elementary School	Brgy. Malamig, Biñan	2/17/2016	3:28 PM	-	ABSENT	<0.30
35	Drinking Fountain 1, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	2/9/2016	2:11 PM	-	ABSENT	<0.30
36	Drinking Fountain 2, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	2/9/2016	2:20 PM	-	ABSENT	<0.30
37	Drinking Fountain, St. Michael School of Biñan	Brgy. Platero, Biñan	2/4/2016	10:36 AM	-	ABSENT	<0.30
38	Sea-oil	Brgy. Platero, Biñan	2/4/2016	11:06 AM	-	ABSENT	0.34
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRILA A. ENICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(FEBRUARY 2016)

LOCATION (SANTA ROSA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Barangay					
1	Alinsod Deepwell	Brgy. Pooc, Sta. Rosa	2/9/2016	9:27 AM	<1	ABSENT	0.30
2	Block 13 Lot 34, Alinsod	Brgy. Pooc, Sta. Rosa	2/9/2016	9:29 AM	-	ABSENT	0.69
3	Source, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	2/9/2016	1:20 PM	<1	ABSENT	<0.30
4	Block 1 Lot 9, Phase 1, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	2/9/2016	1:40 PM	-	ABSENT	<0.30
5	Source, Bayshore 2	Brgy. Sinalhan, Sta. Rosa	2/9/2016	12:27 PM	<1	ABSENT	<0.30
6	Block 9 Lot 14 Bristol Bay St., Bayshore 2	Brgy. Sinalhan, Sta. Rosa	2/9/2016	12:41 PM	-	ABSENT	<0.30
7	Buena Rosa Subdivision Deepwell	Brgy. Macablang, Sta. Rosa	2/2/2016	9:52 AM	<1	ABSENT	<0.30
8	B7 Lot 12, Buena Rosa Subdivision	Brgy. Macablang, Sta. Rosa	2/2/2016	10:05 AM	-	ABSENT	<0.30
9	Cobassuise Deepwell	Brgy. Malitlit, Sta. Rosa	2/2/2016	10:58 AM	<1	ABSENT	<0.30
10	Cobassuise Block 5 Lot 25	Brgy. Malitlit, Sta. Rosa	2/2/2016	11:16 AM	-	ABSENT	<0.30
11	Golden City Ph 1E/3E Deepwell	Brgy. Dila, Sta. Rosa	2/16/2016	9:23 AM	<1	ABSENT	0.47
12	Golden City Ph 1E/3E Block 6 Lot 6	Brgy. Dila, Sta. Rosa	2/16/2016	9:34 AM	-	ABSENT	0.50
13	Golden City Ph 2E Deepwell	Brgy. Dila, Sta. Rosa	2/16/2016	9:55 AM	<1	ABSENT	0.62
14	Golden City Ph 2E Block 13 Lot 5	Brgy. Dila, Sta. Rosa	2/16/2016	10:07 AM	-	ABSENT	<0.30
15	Laguna Bel-Air 1 Block 7 Deepwell	Brgy. Don Jose, Sta. Rosa	2/10/2016	10:33 AM	<1	ABSENT	<0.30
16	Laguna Bel-Air 1 Science HighSchool	Brgy. Don Jose, Sta. Rosa	2/10/2016	10:42 AM	-	ABSENT	<0.30
17	Laguna Bel-Air 1 Block 34 Deepwell	Brgy. Don Jose, Sta. Rosa	2/10/2016	3:28 PM	<1	ABSENT	0.98
18	Laguna Bel-Air 1 Block 34 Lot 59	Brgy. Don Jose, Sta. Rosa	2/10/2016	3:47 PM	-	ABSENT	0.94
19	Laguna Bel-Air 2 Block 71 Deepwell	Brgy. Don Jose, Sta. Rosa	2/1/2016	3:39 PM	<1	ABSENT	1.34
20	Laguna Bel-Air 2 Block 71 Lot 4	Brgy. Don Jose, Sta. Rosa	2/1/2016	3:46 PM	-	ABSENT	1.32
21	Laguna Bel-Air 2 Block 108 Deepwell	Brgy. Don Jose, Sta. Rosa	2/1/2016	4:00 PM	<1	ABSENT	1.00
22	Laguna Bel-Air 2 Block 108 - Church	Brgy. Don Jose, Sta. Rosa	2/1/2016	4:05 PM	-	ABSENT	0.91
23	Laguna Bel-Air 3 Block 2 Deepwell	Brgy. Loma, Sta. Rosa	2/10/2016	2:30 PM	<1	ABSENT	0.70
24	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	Brgy. Loma, Sta. Rosa	2/10/2016	2:40 PM	-	ABSENT	0.73
25	Laguna Bel-Air 3 Block 8	Brgy. Loma, Sta. Rosa	2/10/2016	3:12 PM	<1	ABSENT	<0.30
26	Laguna Bel-Air 3 Block 8 Brenna Model House	Brgy. Loma, Sta. Rosa	2/10/2016	3:20 PM	-	ABSENT	0.34
27	Laguna Bel-Air 3 Block 50 Deepwell	Brgy. Loma, Sta. Rosa	2/10/2016	2:47 PM	<1	ABSENT	0.39
28	Laguna Bel-Air 3 - Block 66 Lot 6, Wallace St.	Brgy. Loma, Sta. Rosa	2/10/2016	2:59 PM	-	ABSENT	0.32
29	Laguna Bel-Air 4 Block 43 Deepwell	Brgy. Don Jose, Sta. Rosa	2/10/2016	10:11 AM	<1	ABSENT	0.62
30	Laguna Bel-Air 4 Block 47 Lot 12	Brgy. Don Jose, Sta. Rosa	2/10/2016	10:20 AM	-	ABSENT	0.56
31	Source, Market Area	Brgy. Balibago, Sta. Rosa	2/9/2016	12:01 PM	<1	ABSENT	0.35
32	Block 9 Lot 2, Terry Town West, Market Area	Brgy. Balibago, Sta. Rosa	2/9/2016	11:41 AM	-	ABSENT	<0.30
33	Metrogate, Tank	Brgy. Tagapo, Sta. Rosa	2/2/2016	9:00 AM	<1	ABSENT	0.72
34	Rosa Subd., Metrogate	Brgy. Macablang, Sta. Rosa	2/2/2016	9:15 AM	-	ABSENT	0.59
35	Block 24 Lot 10, New Santa Rosa Homes (near DW)	Brgy. Dita, Sta. Rosa	2/16/2016	9:23 AM	<1	ABSENT	0.47
36	Block 19 Lot 6, New Santa Rosa Homes	Brgy. Dita, Sta. Rosa	2/16/2016	9:34 AM	-	ABSENT	0.50
37	Source, Pulong Santa Cruz	Brgy. Pulong Sta. Cruz, Sta. Rosa	2/16/2016	9:55 AM	<1	ABSENT	0.62
38	Purok 5, Sitio Arattan	Brgy. Pulong Sta. Cruz, Sta. Rosa	2/16/2016	10:07 AM	-	ABSENT	<0.30
39	Source, Rosewood	Brgy. Halang, Sta. Rosa	2/2/2016	9:17 AM	<1	ABSENT	<0.30
40	Block 3 Lot 19, Rosewood	Brgy. Halang, Sta. Rosa	2/2/2016	9:04 AM	-	ABSENT	1.26
41	Source, Rosewood 2	Brgy. Tagapo, Sta. Rosa	2/2/2016	9:51 AM	<1	ABSENT	0.34
42	Block 14 Lot 14 Phase 2, Rosewood 2	Brgy. Tagapo, Sta. Rosa	2/2/2016	10:07 AM	-	ABSENT	<0.30
43	Rosemont Subdivision Deepwell	Brgy. Macablang, Sta. Rosa	2/2/2016	9:23 AM	<1	ABSENT	<0.30
44	Firehydrant, Rosemont Subdivision	Brgy. Macablang, Sta. Rosa	2/2/2016	9:37 AM	-	ABSENT	<0.30
45	San Lorenzo Royale Deepwell	Brgy. Dita, Sta. Rosa	2/1/2016	2:31 PM	<1	ABSENT	1.13
46	Block 11 Lot 52, San Lorenzo Royale	Brgy. Dita, Sta. Rosa	2/1/2016	2:39 PM	-	ABSENT	1.05
47	Purok 2 near Deepwell, Sinalhan	Brgy. Sinalhan, Sta. Rosa	2/9/2016	12:54 PM	<1	ABSENT	<0.30
48	Purok 4, Sinalhan	Brgy. Sinalhan, Sta. Rosa	2/9/2016	1:14 PM	-	ABSENT	<0.30
49	Sol-Car Deepwell	Brgy. Dita, Sta. Rosa	2/9/2016	1:34 PM	<1	ABSENT	<0.30
50	Front Gate, Sol-Car	Brgy. Dita, Sta. Rosa	2/9/2016	2:09 PM	-	ABSENT	<0.30
51	Deepwell 1, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	2/15/2016	3:24 PM	<1	ABSENT	0.50
52	109 Saraca St., Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	2/15/2016	3:34 PM	-	ABSENT	1.31
53	Deepwell 6, Phase 4C, San Jose Village I	Brgy. Don Jose, Sta. Rosa	2/15/2016	1:48 PM	<1	ABSENT	0.48
54	Deepwell 2, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	2/17/2016	10:16 AM	<1	ABSENT	<0.30
55	Clubhouse, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	2/15/2016	3:11 PM	-	ABSENT	<0.30
56	Clubhouse., San Jose Village I - Phase 4C	Brgy. Don Jose, Sta. Rosa	2/15/2016	2:10 PM	-	ABSENT	0.33
57	Deepwell 11, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	2/17/2016	10:03 AM	<1	ABSENT	<0.30
58	Clubhouse, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	2/15/2016	2:58 PM	-	ABSENT	1.38
59	Deepwell 7, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	2/15/2016	2:23 PM	<1	ABSENT	1.11
60	Clubhouse, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	2/15/2016	2:35 PM	-	ABSENT	1.10

61	Booster Tank, Santa Rosa Estates	Brgy. Don Jose, Sta. Rosa	2/17/2016	10:45 AM	<1	ABSENT	<0.30
62	Clubhouse, Santa Rosa Village II	Brgy. Don Jose, Sta. Rosa	2/17/2016	10:32 AM	-	ABSENT	<0.30
63	Clubhouse, Santa Rosa Estates I	Brgy. Don Jose, Sta. Rosa	2/17/2016	10:55 AM	-	ABSENT	<0.30
64	Clubhouse, Santa Rosa Estates II	Brgy. Don Jose, Sta. Rosa	2/17/2016	11:09 AM	-	ABSENT	<0.30
65	Southville Caingin Phase 1, Block 52 Lot 23	Brgy. Caingin, Sta. Rosa	2/2/2016	3:01 PM	<1	ABSENT	<0.30
66	Southville Caingin Phase 1, Block 57 Lot 17	Brgy. Caingin, Sta. Rosa	2/2/2016	2:44 PM	-	ABSENT	<0.30
67	Southville Caingin Phase 5, Block 1 Lot 34	Brgy. Pooc, Sta. Rosa	2/2/2016	2:17 PM	<1	ABSENT	<0.30
68	Southville Caingin Phase 2, Block 46 Lot 2	Brgy. Pooc, Sta. Rosa	2/2/2016	2:29 PM	-	ABSENT	<0.30
69	Tank, South Hampton	Brgy. Balibago, Sta. Rosa	2/2/2016	3:09 PM	<1	ABSENT	0.39
70	Clubhouse, South Hampton	Brgy. Balibago, Sta. Rosa	2/1/2016	3:19 PM	-	ABSENT	<0.30
71	Terra Fortuna Deepwell	Brgy. Malitlit, Sta. Rosa	2/16/2016	2:31 PM	<1	ABSENT	0.97
72	Block 11 Lot 16, Terra Fortuna	Brgy. Malitlit, Sta. Rosa	2/16/2016	2:40 PM	-	ABSENT	0.85
73	Villa Esmeralda Deepwell	Brgy. Dita, Sta. Rosa	2/1/2016	2:59 PM	<1	ABSENT	1.31
74	Villa Esmeralda Block (Alabaster St.)	Brgy. Dita, Sta. Rosa	2/1/2016	2:50 PM	-	ABSENT	0.91
75	Villa Las Casas Deepwell	Brgy. Malitlit, Sta. Rosa	2/2/2016	10:38 AM	<1	ABSENT	0.30
76	Villa Las Casas Oval Entrance	Brgy. Malitlit, Sta. Rosa	2/2/2016	10:46 AM	-	ABSENT	<0.30
77	Reservoir, Mesaland	Brgy. Don Jose, Sta. Rosa	2/15/2016	12:31 PM	<1	ABSENT	1.22
78	Block 6 Lot 8 Buklod Diwa	Brgy. Pulong Sta. Cruz, Sta. Rosa	2/15/2016	12:57 PM	<1	ABSENT	1.34
79	Bakery	Brgy. Malusak, Sta. Rosa	2/9/2016	11:17 AM	-	ABSENT	0.46
80	Block 11 Lot 2, JB Village	Brgy. Balibago, Sta. Rosa	2/10/2016	12:30 PM	-	ABSENT	0.83
81	#1780	Brgy. Dita, Sta. Rosa	2/9/2016	2:21 PM	-	ABSENT	0.69
82	#31 J. P. Rizal Blvd.	Brgy. Tagapo, Sta. Rosa	2/2/2016	8:57 AM	-	ABSENT	1.18
83	Drinking Fountain, Caingin Elementary School	Brgy. Caingin, Sta. Rosa	2/2/2016	9:30 AM	-	ABSENT	<0.30
84	Drinking Fountain, Dila Elementary School	Brgy. Dila, Sta. Rosa	2/9/2016	9:43 AM	-	ABSENT	0.31
85	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	Brgy. Malusak, Sta. Rosa	2/10/2016	8:47 AM	-	ABSENT	0.32
86	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	Brgy. Malusak, Sta. Rosa	2/10/2016	8:54 AM	-	ABSENT	0.79
87	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	Brgy. Tagapo, Sta. Rosa	2/10/2016	9:03 AM	-	ABSENT	0.35
PNSDW LIMIT						<500	ABSENT

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(FEBRUARY 2016)

#	LOCATION (CABUYAO CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
	Sampling Point	Barangay					
1	Cabuyao Central Deepwell	Brgy. Pulo, Cabuyao	2/16/2016	11:12 AM	<1	ABSENT	0.47
2	Cabuyao Central Clubhouse	Brgy. Pulo, Cabuyao	2/16/2016	11:26 AM	-	ABSENT	<0.30
3	Block 3 Lot 17, Celestine Phase 1	Brgy. Marinig, Cabuyao	2/9/2016	10:31 AM	<1	ABSENT	1.08
4	Block 26 Lot 4, Celestine Phase 1	Brgy. Marinig, Cabuyao	2/9/2016	11:14 AM	-	ABSENT	0.74
5	Source, Celestine Phase 2	Brgy. Marinig, Cabuyao	2/9/2016	10:54 AM	<1	ABSENT	0.57
6	Celestine Phase 2 Block 11 Lot 19	Brgy. Marinig, Cabuyao	2/9/2016	10:58 AM	-	ABSENT	0.59
7	Celestine Ville Deepwell	Brgy. Gulod, Cabuyao	2/3/2016	11:05 AM	<1	ABSENT	0.53
8	Guardhouse, Celestine Ville	Brgy. Gulod, Cabuyao	2/3/2016	11:32 AM	-	ABSENT	<0.30
9	Mabuhay Phase 1 Block 101 Deepwell	Brgy. Mamatid, Cabuyao	2/3/2016	10:06 AM	<1	ABSENT	<0.30
10	Mabuhay Phase 1 Block 95 Lot 57	Brgy. Mamatid, Cabuyao	2/3/2016	10:21 AM	-	ABSENT	<0.30
11	Mabuhay Phase 2 Block 141 Deepwell	Brgy. Mamatid, Cabuyao	2/3/2016	10:36 AM	<1	ABSENT	<0.30
12	Mabuhay Phase 2 Block 4 Lot 20	Brgy. Mamatid, Cabuyao	2/3/2016	10:45 AM	-	ABSENT	<0.30
13	Mabuhay Phase 2 Block 198 Deepwell	Brgy. Mamatid, Cabuyao	2/3/2016	9:37 AM	<1	ABSENT	<0.30
14	Mabuhay Phase 2 Block 222 Lot 20	Brgy. Mamatid, Cabuyao	2/3/2016	9:49 AM	-	ABSENT	<0.30
15	Mabuhay Phase 3 Cluster Deepwell	Brgy. Mamatid, Cabuyao	2/2/2016	12:52 PM	<1	ABSENT	<0.30
16	Mabuhay Phase 3 Cluster Block 1 Lot 17	Brgy. Mamatid, Cabuyao	2/2/2016	12:44 PM	-	ABSENT	<0.30
17	Mabuhay Phase 3 Luxury Deepwell	Brgy. Mamatid, Cabuyao	2/2/2016	12:28 PM	<1	ABSENT	<0.30
18	Mabuhay Phase 3 Luxury Block 19 Lot 13	Brgy. Mamatid, Cabuyao	2/2/2016	12:37 PM	-	ABSENT	<0.30
19	Mabuhay Phase 5 Deepwell	Brgy. Mamatid, Cabuyao	2/2/2016	12:07 PM	<1	ABSENT	<0.30
20	Mabuhay Phase 5 Block 31 Lot 134	Brgy. Mamatid, Cabuyao	2/2/2016	12:15 PM	-	ABSENT	<0.30
21	Source, Multi-Land III	Brgy. Sala, Cabuyao	2/9/2016	1:01 PM	<1	ABSENT	<0.30
22	Guardhouse, Multi-Land III	Brgy. Sala, Cabuyao	2/9/2016	1:10 PM	-	ABSENT	<0.30
23	Multi-Land IV Deepwell	Brgy. San Isidro, Cabuyao	2/2/2016	11:47 AM	<1	ABSENT	<0.30
24	Multi-Land IV Block 3 Lot 33	Brgy. San Isidro, Cabuyao	2/2/2016	11:35 AM	-	ABSENT	<0.30
25	Source, Niugan	Brgy. Niugan, Cabuyao	2/16/2016	1:35 PM	<1	ABSENT	0.53
26	Patricia's Apartment, Niugan	Brgy. Niugan, Cabuyao	2/16/2016	1:42 PM	-	ABSENT	0.47
27	Southville Tank 1 Blk 25 Deepwell	Brgy. Marinig, Cabuyao	2/9/2016	11:38 AM	<1	ABSENT	<0.30
28	Southville Tank 1 Blk 19 Lot 33	Brgy. Marinig, Cabuyao	2/9/2016	11:52 AM	-	ABSENT	<0.30
29	Southville Tank 4 Blk 45 Deepwell	Brgy. Niugan, Cabuyao	2/9/2016	12:36 PM	<1	ABSENT	<0.30
30	Southville Tank 4 Blk 40 Lot 132	Brgy. Niugan, Cabuyao	2/9/2016	12:26 PM	-	ABSENT	<0.30
31	Southville Tank 5 Blk 54 Deepwell	Brgy. Niugan, Cabuyao	2/16/2016	12:58 PM	<1	ABSENT	<0.30
32	Southville Tank 5 Blk 47 Lot 101	Brgy. Niugan, Cabuyao	2/16/2016	1:15 PM	-	ABSENT	<0.30
33	Willow Park, Tank	Brgy. Pulo, Cabuyao	2/16/2016	12:15 PM	<1	ABSENT	<0.30
34	Guardhouse, Willow Park	Brgy. Pulo, Cabuyao	2/16/2016	12:23 PM	-	ABSENT	<0.30
35	Matang Tubig Spring	Brgy. Casile, Cabuyao	2/15/2016	12:06 PM	<1	ABSENT	1.36
36	#253 Elsol Subdivision, Cabuyao City	Brgy. Elsol, Cabuyao	2/9/2016	1:41 PM	-	ABSENT	<0.30
37	Wash Area, Niugan Elementary School	Brgy. Niugan, Cabuyao	2/16/2016	2:00 OM	<1	ABSENT	0.39
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(FEBRUARY 2016)

LOCATION (CALAMBA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Address					
1	Deepwell 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	2/23/2016	5:55 PM	<1	ABSENT	0.48
2	Block 39 Lot 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	2/23/2016	5:06 PM	-	ABSENT	0.32
3	Deepwell 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	2/23/2016	5:14 PM	<1	ABSENT	0.61
4	Block 23 Lot 31, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	2/23/2016	5:22 PM	-	ABSENT	0.39
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
Telephone Number: (049) 534 1627 · (02) 519 4887




LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(FEBRUARY 2016)

LOCATION (ALAMINOS)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Address					
1	Source, BellaVita Homes	Brgy. San Andres, Alaminos	2/23/2016	4:00 PM	<1	ABSENT	0.56
2	Block 21 Lot 18, BellaVita Homes	Brgy. San Andres, Alaminos	2/23/2016	4:18 PM	-	ABSENT	0.41
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
 Legend: *Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:



CYRLA A. ERICA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)



AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAAWATER CORPORATION
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 534 1627 · (02) 519 4887




LAGUNA AAAWATER CORPORATION LABORATORY
 MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
 (FEBRUARY 2016)

LOCATION (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*		
#	Sampling Point	Address						
1	Deepwell Source (after DMI 65)	San Luis Sports Complex, Sta. Cruz, Laguna		2/23/2016	1:43 PM	<1	ABSENT	0.60
2	Canteen No. 4 in front of the Laguna University Administration Bldg.	San Luis Sports Complex, Sta. Cruz, Laguna		2/23/2016	2:21 PM	-	ABSENT	0.45
PNSDW LIMIT						<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
 Legend: *Detection Limit = <0.3 mg/L

Prepared by:



 CYRIL A. ERICA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)

Certified Correct:



 AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAAWATER CORPORATION
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 534 1627 · (02) 519 4887