

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY	: BIÑAN	MONTH	: JUNE	YEAR	: 2016
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018		

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN							
1	Laguna Well Field 1	Source	6/29/2016	8:00 AM	<1	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	Source	6/8/2016	1:57 PM	-	ABSENCE	ABSENCE
3	Blk 3 Lot 28, Santol st., Phase 4C, San Jose Village I	Distribution	6/8/2016	2:02 PM	-	ABSENCE	ABSENCE
4	Pump 2, Jacana St., Phase 3B, San Jose Village I	Source	6/6/2016	10:22 AM	<1	ABSENCE	ABSENCE
5	Blk 2 Lot 18, Jacana St., Phase 3B, San Jose Village I	Distribution	6/7/2016	3:05 PM	200	ABSENCE	ABSENCE
6	Pump 11, Phase 5, San Jose Village II	Source	6/6/2016	11:16 AM	120	ABSENCE	ABSENCE
7	Blk 1 Lot 23, Camia St., Phase 5, San Jose Village II	Distribution	6/6/2016	11:06 AM	<1	ABSENCE	ABSENCE
8	Clubhouse, Phase 6, San Jose Village III	Distribution	6/6/2016	11:16 AM	<1	ABSENCE	ABSENCE
BRGY. CANLALAY							
9	#84 A. Bonifacio St.	Distribution	6/7/2016	1:00 PM	2	ABSENCE	ABSENCE
10	Golden City Canlalay Clubhouse	Distribution	6/14/2016	9:08 AM	<1	ABSENCE	ABSENCE
BRGY. DELA PAZ							
11	9028 WP GP Sta. Bernardina St. Kapitana Dela Paz	Source	6/7/2016	12:31 PM	-	ABSENCE	ABSENCE
12	Barangay Hall	Distribution	6/7/2016	12:42 PM	75	ABSENCE	ABSENCE
13	Drinking Fountain, Dela Paz Elementary School	Distribution	6/7/2016	11:37 AM	450	ABSENCE	ABSENCE
BRGY. GANADO							
14	Drinking Fountain, Ganado Elementary School	Distribution	6/8/2016	8:32 AM	12	ABSENCE	ABSENCE
BRGY. HALANG							
15	9999 WP Metroville Complex	Source	6/14/2016	9:42 AM	110	ABSENCE	ABSENCE
16	Clubhouse, Metroville Complex	Distribution	6/14/2016	10:01 AM	-	ABSENCE	ABSENCE
BRGY. LANGKIWA							
17	Block 3 Lot 9 Phase 2, Southville Langkiwa	Distribution	6/27/2016	2:07 PM	-	ABSENCE	ABSENCE
18	Block 57 Lot 5 Phase 1, Southville Langkiwa	Distribution	6/27/2016	2:20 PM	9	ABSENCE	ABSENCE
19	Block 20 Lot 7 Phase 3, Southville Langkiwa	Distribution	6/27/2016	2:32 PM	-	ABSENCE	ABSENCE
20	Block 21 Lot 8 Phase 2, Southville Langkiwa	Distribution	6/27/2016	2:46 PM	<1	ABSENCE	ABSENCE
21	Block 18 Lot 11 Phase 4, Southville Langkiwa	Distribution	6/27/2016	3:03 PM	-	ABSENCE	ABSENCE
22	Block 31 Lot 27, Phase 3, Southville Langkiwa	Distribution	6/27/2016	3:19 PM	<1	ABSENCE	ABSENCE
23	Drinking Fountain, Langkiwa Elementary School	Distribution	6/27/2016	1:56 PM	-	ABSENCE	ABSENCE
BRGY. LOMA							
24	Block 2 Lot 16, Phase 1, Laguna Bel-Air 3	Source	6/6/2016	11:11 AM	-	ABSENCE	ABSENCE
25	Hillcrest Road, Block 2, Laguna Bel-Air 3	Distribution	6/6/2016	11:22 AM	<1	ABSENCE	ABSENCE
26	4NR Block 99, Phase 4, Laguna Bel-Air 3	Source	6/6/2016	12:01 PM	-	ABSENCE	ABSENCE
27	Brenna Model House, Phase 1, Laguna Bel-Air 3	Distribution	6/6/2016	12:09 PM	<1	ABSENCE	ABSENCE
28	Block 50, Phase 2, Laguna Bel-Air 3	Source	6/6/2016	11:36 AM	-	ABSENCE	ABSENCE
29	Block 61 Lot 20, Laguna Bel-Air 3	Distribution	6/6/2016	11:51 AM	<1	ABSENCE	ABSENCE
30	Drinking Fountain, Loma Elementary School	Distribution	6/27/2016	3:42 PM	-	ABSENCE	ABSENCE
BRGY. MALAMIIG							
31	Block 5 Lot 16	Distribution	6/27/2016	4:04 PM	<1	ABSENCE	ABSENCE
BRGY. MAMPLASAN							
32	Tank, Verdana Homes Subdivision	Source	6/29/2016	4:44 PM	260	ABSENCE	ABSENCE
33	Clubhouse, Verdana Homes Subdivision	Distribution	6/27/2016	10:54 AM	-	ABSENCE	ABSENCE
BRGY. POBLACION							
34	9018 WP Public Market 4024 Town Proper	Source	6/7/2016	11:21 AM	-	ABSENCE	ABSENCE
BRGY. PLATERO							

35	Drinking Fountain, St. Michael School of Biñan	Distribution	6/7/2016	8:54 AM	-	ABSENCE	ABSENCE
36	Sea-oil, National Road	Distribution	6/7/2016	9:07 AM	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO							
37	9022 Water Pump (WP) Faraon Subdivision	Source	6/7/2016	10:09 AM	-	ABSENCE	ABSENCE
38	Block 5 Lot 12, Margarita Homes Subdivision	Distribution	6/7/2016	9:31 AM	28	ABSENCE	ABSENCE
39	Drinking Fountain 1, Faraon Elementary School	Distribution	6/7/2016	10:35 AM	-	ABSENCE	ABSENCE
40	Cistern Tank, Pavillion Mall	Distribution	6/22/2016	11:23 AM	<1	ABSENCE	ABSENCE
41	Jollibee, Pavillion Mall	Distribution	6/22/2016	10:35 AM	-	ABSENCE	ABSENCE
BRGY. SANTO NIÑO							
42	Jollibee National Hi-Way	Distribution	6/22/2016	11:55 AM	2	ABSENCE	ABSENCE
BRGY. SAN VICENTE							
43	9001 GP San Vicente	Source	6/8/2017	10:54 AM	-	ABSENCE	ABSENCE
44	B8 L6, Bayabas St., Olivarez 7	Distribution	6/8/2017	10:35 AM	6	ABSENCE	ABSENCE
45	Cistern Tank, Central Mall	Distribution	6/22/2016	10:55 AM	<1	ABSENCE	ABSENCE
BRGY. SANTO TOMAS							
46	Phase 2, Adelina Complex III Subdivision	Source	6/8/2017	11:20 AM	-	ABSENCE	ABSENCE
47	Gate Entrance, Adelina Complex III Subdivision	Distribution	6/8/2017	11:31 AM	1	ABSENCE	ABSENCE
48	1 LT Water Pump, Phase 1B, Olivarez Homes South	Source	6/14/2016	2:00 PM	<1	ABSENCE	ABSENCE
49	Block 1 Lot 26, Phase 3, Olivarez Homes South	Distribution	6/14/2016	1:33 PM	-	ABSENCE	ABSENCE
50	5555 Block 1, Phase 4, Olivarez Homes South	Source	6/14/2016	12:55 PM	3	ABSENCE	ABSENCE
51	Block 2 ot 9, Phase 4, Olivarez Homes South	Distribution	6/14/2016	1:06 PM	-	ABSENCE	ABSENCE
52	Pump House, Kalibo St., South City Homes	Source	6/8/2017	9:45 AM	-	ABSENCE	ABSENCE
53	Block 76 Lot 6, Tangub St., Pragmatic	Distribution	6/8/2017	10:11 AM	2	ABSENCE	ABSENCE
54	South Plains II Subdivision	Source	6/8/2017	9:26 AM	-	ABSENCE	ABSENCE
55	Block 11 Lot 2, South Plains II Subdivision	Distribution	6/8/2017	9:14 AM	3	ABSENCE	ABSENCE
56	Pump, Amsterdam St., Phase 2, Town & Country	Source	6/8/2017	11:52 AM	-	ABSENCE	ABSENCE
57	Block 35 Lot 21, Town & Country	Distribution	6/8/2017	12:06 PM	<1	ABSENCE	ABSENCE
58	Block 2 Lot 5, Town & Country	Distribution	6/14/2016	2:14 PM	<1	ABSENCE	ABSENCE
BRGY. SORO - SORO							
59	9067 Soro-soro	Source	6/14/2016	11:12 AM	7	ABSENCE	ABSENCE
60	#76 Soro-Soro	Distribution	6/14/2016	10:22 AM	-	ABSENCE	ABSENCE
BRGY. TUBIGAN							
61	#60 Forinda Compound	Distribution	6/14/2016	11:38 AM	-	ABSENCE	ABSENCE
BRGY. ZAPOTE							
62	Source, Althea	Source	6/28/2016	1:19 PM	-	ABSENCE	ABSENCE
63	Construction House, Althea	Distribution	6/28/2016	1:24 PM	<1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		63	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES :³Philippine National Standard for Drinking Water, 2007

:⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

7/7/2016 9:00am

DATE/TIME

7/11/2016 3:10 p.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY	: SANTA ROSA	MONTH	: JUNE	YEAR	: 2016
DOH ACCREDITATION NO.	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018		

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO							
1	#1354 Facundo Compound	Distribution	6/21/2016	11:57 AM	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	Source	6/13/2016	1:15 PM	<1	ABSENCE	ABSENCE
3	Block 1 Lot 5, South Hampton	Distribution	6/13/2016	1:06 PM	-	ABSENCE	ABSENCE
4	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	Distribution	6/21/2016	11:42 AM	7	ABSENCE	ABSENCE
BRGY. CAINGIN							
5	9002 Block 53, Phase 4, Southville	Source	6/21/2016	12:55 PM	<1	ABSENCE	ABSENCE
6	Block 52 Lot 23, Phase 1, Southville	Distribution	6/21/2016	1:03 PM	-	ABSENCE	ABSENCE
BRGY. DILA							
7	Phase 3E, Mabuhay Homes 2000	Source	6/21/2016	1:23 PM	5	ABSENCE	ABSENCE
8	Block 2 Lot 10, Mabuhay Homes 2000	Distribution	6/21/2016	1:33 PM	-	ABSENCE	ABSENCE
9	Block 12, Phase 2E, Mabuhay Homes 2000	Source	6/21/2016	2:12 PM	<1	ABSENCE	ABSENCE
10	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	Distribution	6/21/2016	1:59 PM	-	ABSENCE	ABSENCE
11	Drinking Fountain, Dila Elementary School	Distribution	6/20/2016	1:40 PM	10	ABSENCE	ABSENCE
BRGY. DITA							
12	Block 24 Lot 2, New Santa Rosa Homes	Source	6/21/2016	2:32 PM	<1	ABSENCE	ABSENCE
13	Block 19 Lot 11, New Santa Rosa Homes	Distribution	6/21/2016	2:45 PM	-	ABSENCE	ABSENCE
14	Block 4 Lot 32, San Lorenzo Royale	Source	6/13/2016	10:19 AM	20	ABSENCE	ABSENCE
15	Block 11 Lot 52, San Lorenzo Royale	Distribution	6/13/2016	10:08 AM	-	ABSENCE	ABSENCE
16	Water Tank, SolCar Ville Subdivision	Source	6/21/2016	3:15 PM	<1	ABSENCE	ABSENCE
17	Front Gate, SolCar Ville Subdivision	Distribution	6/21/2016	3:28 PM	-	ABSENCE	ABSENCE
18	Water Tank, Villa Esmeralda	Source	6/13/2016	10:42 AM	<1	ABSENCE	ABSENCE
19	Alabaster St., Villa Esmeralda	Distribution	6/13/2016	10:32 AM	-	ABSENCE	ABSENCE
20	#1780 National Road	Distribution	6/20/2016	1:28 PM	-	ABSENCE	ABSENCE
21	Lima Express Ice Plant, Inc.	Distribution	6/22/2016	2:05 PM	<1	ABSENCE	ABSENCE
BRGY. DON JOSE							
22	Block 7 Lot 62, Phase 3, Laguna Bel-Air	Source	6/6/2016	1:14 PM	2	ABSENCE	ABSENCE
23	Science HighSchool, Phase 1, Laguna Bel-Air	Distribution	6/6/2016	1:47 PM	-	ABSENCE	ABSENCE
24	Block 34 Lot 14, Phase 1, Laguna Bel-Air	Source	6/7/2016	3:47 PM	1	ABSENCE	ABSENCE
25	#60 Cypress St., Phase 1, Laguna Bel-Air	Distribution	6/6/2016	12:27 PM	-	ABSENCE	ABSENCE
26	Clubhouse, Block 62, Laguna Bel-Air	Distribution	6/6/2016	2:00 PM	62	ABSENCE	ABSENCE
27	Water Pump, Block 71, Phase 4, Laguna Bel-Air	Source	6/6/2016	10:09 AM	-	ABSENCE	ABSENCE
28	Block 71 Lot 4, Phase 2, Laguna Bel-Air	Distribution	6/6/2016	10:18 AM	<1	ABSENCE	ABSENCE
29	Block 108, Phase 5, Laguna Bel-Air	Source	6/6/2016	10:34 AM	-	ABSENCE	ABSENCE
30	Church, Block 108, Phase 2, Laguna Bel-Air	Distribution	6/6/2016	10:52 AM	130	ABSENCE	ABSENCE
31	1NR Block 43, Laguna Bel-Air IV	Source	6/6/2016	1:26 PM	-	ABSENCE	ABSENCE
32	Block 47 Lot 12 Laguna Bel-Air IV	Distribution	6/6/2016	1:38 PM	4	ABSENCE	ABSENCE
33	8001, Pump 1, Acacia St., Santa Rosa Village I	Source	6/6/2016	10:07 AM	28	ABSENCE	ABSENCE
34	Clubhouse., Santa Rosa Village I	Distribution	6/6/2016	10:16 AM	<1	ABSENCE	ABSENCE
35	Pump 9 & 10, Rembrandr St., Santa Rosa Estates I	Source	6/6/2016	9:25 AM	<1	ABSENCE	ABSENCE
36	101 Elde France St., Phase 4A, Santa Rosa Village II	Distribution	6/6/2016	9:55 AM	<1	ABSENCE	ABSENCE
37	Clubhouse, Santa Rosa Estates I	Distribution	6/6/2016	9:32 AM	<1	ABSENCE	ABSENCE
38	Reservoir, Hacienda Sta. Elena	Distribution	6/29/2016	11:27 AM	<1	ABSENCE	ABSENCE
BRGY. KANLURAN							
39	Malusak Bakery, #621 Rizal Boulevard	Distribution	6/7/2016	8:53 AM	-	ABSENCE	ABSENCE

BRGY. MACABLING							
40	Deepwell, Buena Rosa 9 Subdivision	Source	6/21/2016	9:52 AM	1	ABSENCE	ABSENCE
41	Block 3 Lot 1, Phase 2, Buena Rosa 9 Subdivision	Distribution	6/21/2016	10:01 AM	-	ABSENCE	ABSENCE
42	Deepwell, Corinthian Subdivision	Source	6/21/2016	9:17 AM	-	ABSENCE	ABSENCE
43	Guardhouse, Corinthian Subdivision	Distribution	6/21/2016	9:37 AM	-	ABSENCE	ABSENCE
44	Deepwell, Rosemont Subdivision	Source	6/21/2016	10:32 AM	5	ABSENCE	ABSENCE
45	Block 4 Lot 7, Rosemont Subdivision	Distribution	6/21/2016	10:49 AM	-	ABSENCE	ABSENCE
BRGY. MALITLIT							
46	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	Source	6/13/2016	11:00 AM	<1	ABSENCE	ABSENCE
47	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	Distribution	6/13/2016	11:08 AM	-	ABSENCE	ABSENCE
48	Main Road, Phase 2, Terra Fortuna	Source	6/13/2016	12:10 PM	<1	ABSENCE	ABSENCE
49	Block 11 Lot 16, Terra Fortuna	Distribution	6/13/2016	12:19 PM	-	ABSENCE	ABSENCE
50	9999 W, Villa Las Casas	Source	6/13/2016	11:21 AM	<1	ABSENCE	ABSENCE
51	Block 1 Lot 17, Villa Las Casas	Distribution	6/13/2016	11:41 AM	-	ABSENCE	ABSENCE
BRGY. MARKET AREA							
52	Source, Market Area	Source	6/7/2016	9:36 AM	-	ABSENCE	ABSENCE
53	Block 9 Lot 2, Terry Town West	Distribution	6/7/2016	9:29 AM	<1	ABSENCE	ABSENCE
BRGY. POOC							
54	Deepwell, Alinsod	Source	6/21/2016	11:47 AM	-	ABSENCE	ABSENCE
55	9999 Water Pump, Phase 5, Southville	Source	6/21/2016	12:39 PM	<1	ABSENCE	ABSENCE
56	Block 46 Lot 2, Phase 2, Southville	Distribution	6/21/2016	12:39 PM	-	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ							
57	Water Pump, Pulong Sta. Cruz	Source	6/22/2016	3:15 PM	<1	ABSENCE	ABSENCE
58	Purok 5, Sitio Arattan	Distribution	6/21/2016	12:35 PM	-	ABSENCE	ABSENCE
59	Block 6 Lot 8, Buklod Diwa	Distribution	6/29/2016	11:52 AM	<1	ABSENCE	ABSENCE
BRGY. SINALHAN							
60	Water Pump, Bayshore I	Source	6/7/2016	10:05 AM	270	ABSENCE	ABSENCE
61	Block 1 Lot 23, Bayshore I	Distribution	6/7/2016	10:13 AM	-	ABSENCE	ABSENCE
62	Block 9 Lot 14, Bristol Bay St., Bayshore II	Distribution	6/7/2016	9:52 AM	20	ABSENCE	ABSENCE
63	4026, Sinalhan Road, Purok 2	Source	6/7/2016	10:29 AM	-	ABSENCE	ABSENCE
64	Amoranto Compound, Phase 2, Sinalhan	Distribution	6/7/2016	10:39 AM	1	ABSENCE	ABSENCE
BRGY. STO. DOMINGO							
65	Laguna Water Head Office, One Evotech Bldg.	Distribution	6/29/2016	12:15 PM	<1	ABSENCE	ABSENCE
66	Clubhouse Santa Rosa Estates II	Distribution	6/6/2016	9:41 AM	8	ABSENCE	ABSENCE
BRGY. TAGAPO							
67	Water Pump, Metrogate	Source	6/20/2016	3:21 PM	-	ABSENCE	ABSENCE
68	Clubhouse, Metrogate	Distribution	6/20/2016	3:29 PM	-	ABSENCE	ABSENCE
69	Water Pump, Rosewood	Source	6/20/2016	2:55 PM	18	ABSENCE	ABSENCE
70	Block 4 Lot 12, Rosewood	Distribution	6/20/2016	3:04 PM	-	ABSENCE	ABSENCE
71	Block 6 Lot 8, Phase 2, Rosewood II	Distribution	6/20/2016	2:44 PM	92	ABSENCE	ABSENCE
72	#31 JP Rizal Boulevard	Distribution	6/20/2016	2:31 PM	-	ABSENCE	ABSENCE
73	Water Pump, Buena Rosa 10 Subdivision	Source	6/20/2016	2:06 PM	5	ABSENCE	ABSENCE
74	Block 1 Lot 43, Buena Rosa 10 Subdivision	Distribution	6/20/2016	2:19 PM	-	ABSENCE	ABSENCE
75	Drinking Fountain, Front Gate, Central I Elem. Sch.	Distribution	6/22/2016	2:40 PM	-	ABSENCE	ABSENCE
76	Cistern Tank, SM Sta. Rosa	Distribution	6/22/2016	1:27 PM	<1	ABSENCE	ABSENCE
77	Crepes Delicious, SM Sta. Rosa	Distribution	6/22/2016	1:37 PM	-	ABSENCE	ABSENCE
78	Cistern Tank, Robinson's Mall	Distribution	6/22/2016	12:17 PM	15	ABSENCE	ABSENCE
79	Chummie, Robinson's Mall	Distribution	6/22/2016	12:24 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		79	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

:⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

7/7/2016 9:00am

DATE/TIME

7/11/2016 3:25 P.M.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CABUYAO	MONTH : JUNE	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²		
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>	
BRGY. BIGAA								
1	#253 Elsol Subdivision	Distribution	6/27/2016	8:48 AM	-	ABSENCE	ABSENCE	
BRGY. CASILE								
2	Matang Tubig Spring	Source	6/29/2016	10:54 AM	-	ABSENCE	ABSENCE	
BRGY. GULOD								
3	Block 12, Noah St., Celestine Ville	Source	6/14/2016	10:30 AM	<1	ABSENCE	ABSENCE	
4	Guardhouse, Celestine Ville Avenue, Celestine Ville	Distribution	6/14/2016	10:39 AM	-	ABSENCE	ABSENCE	
BRGY. MAMATID								
5	Tank, Buena Rosario Subdivision	Source	6/14/2016	9:01 AM	5	ABSENCE	ABSENCE	
6	Block 7 Lot 6, Buena Rosario Subdivision	Distribution	6/14/2016	8:50 AM	-	ABSENCE	ABSENCE	
7	Block 101 Samar st., Phase 2, Mabuhay City	Source	6/14/2016	9:23 AM	8	ABSENCE	ABSENCE	
8	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	Distribution	6/14/2016	9:31 AM	-	ABSENCE	ABSENCE	
9	Block 141, Carmona St., Phase 2, Mabuhay City	Source	6/14/2016	10:10 AM	<1	ABSENCE	ABSENCE	
10	Block 4 Lot 22, Phase 2, Mabuhay City	Distribution	6/14/2016	10:17 AM	-	ABSENCE	ABSENCE	
11	Block 198, Galacia St., Phase 2, Mabuhay City	Source	6/14/2016	9:42 AM	7	ABSENCE	ABSENCE	
12	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	Distribution	6/14/2016	9:59 AM	-	ABSENCE	ABSENCE	
13	Panganig St., Phase 3 Cluster, Mabuhay City	Source	6/21/2016	10:12 AM	<1	ABSENCE	ABSENCE	
14	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	Distribution	6/23/2016	10:01 AM	-	ABSENCE	ABSENCE	
15	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	Source	6/21/2016	10:37 AM	1	ABSENCE	ABSENCE	
16	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	Distribution	6/21/2016	11:17 AM	-	ABSENCE	ABSENCE	
17	Joshua St., Phase 5, Mabuhay City	Source	6/21/2016	9:53 AM	-	ABSENCE	ABSENCE	
18	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	Distribution	6/23/2016	9:42 AM	-	ABSENCE	ABSENCE	
BRGY. MARINIG								
19	Block 3 Lot 17, Phase 1, Celestine Homes	Source	6/7/2016	10:55 AM	<1	ABSENCE	ABSENCE	
20	Block 23, Lot 10, Phase 1, Celestine Homes	Distribution	6/7/2016	11:46 AM	-	ABSENCE	ABSENCE	
21	Block 9, Carnation St., Phase 2, Celestine Homes	Source	6/7/2016	11:33 AM	<1	ABSENCE	ABSENCE	
22	Block 11 Lot 9, Phase 2, Celestine Homes	Distribution	6/7/2016	11:23 AM	-	ABSENCE	ABSENCE	
23	Block 25, Phase 3, Southville	Source	6/7/2016	9:30 AM	-	ABSENCE	ABSENCE	
24	Block 19 Lot 33, Phase 3, Southville	Distribution	6/7/2016	9:51 AM	<1	ABSENCE	ABSENCE	
BRGY. NIUGAN								
25	Water Pump, Niugan Elementary School Compound	Source	6/20/2016	12:58 PM	<1	ABSENCE	ABSENCE	
26	Patricia's Apartment, St. Francis 7	Distribution	6/20/2016	1:12 PM	-	ABSENCE	ABSENCE	
27	Block 45, Phase 8, Southville	Source	6/7/2016	10:13 AM	-	ABSENCE	ABSENCE	
28	Block 43 Lot 99, Southville	Distribution	6/7/2016	10:30 AM	<1	ABSENCE	ABSENCE	
29	Block 54, Phase 10, Southville	Source	6/21/2016	11:17 AM	<1	ABSENCE	ABSENCE	
30	Block 43 Lot 99, Phase 10, Southville	Distribution	6/21/2016	11:27 AM	-	ABSENCE	ABSENCE	
BRGY. PULO								
31	Block 12 Lot 22, Cabuyao Central	Source	6/20/2016	12:01 PM	2	ABSENCE	ABSENCE	
32	Clubhouse, Narra Avenue, Cabuyao Central	Distribution	6/20/2016	12:10 PM	-	ABSENCE	ABSENCE	
33	Block 11, Willow Park Homes	Source	6/20/2016	12:37 PM	1	ABSENCE	ABSENCE	
34	Guardhouse, Main St., Willow Park Homes	Distribution	6/20/2016	12:45 PM	-	ABSENCE	ABSENCE	
BRGY. SALA								
35	Guardhouse, Main St., Multiland III	Distribution	6/7/2016	9:10 AM	<1	ABSENCE	ABSENCE	
BRGY. SAN ISIDRO								
36	Source, Multiland IV	Source	6/21/2016	9:07 AM	-	ABSENCE	ABSENCE	

37	Block 3 Lot 33, Multiland IV	Distribution	6/21/2016	9:18 AM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		37	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CERTIFIED CORRECT




CYRIL A. ERICA, RMT

AMPARO C. CAÑAMO

Analyst (License No. 0054161)

Head of Laboratory

DATE/TIME

DATE/TIME

7/7/2016 9:00am

7/11/2016 3:28 p.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY	: CALAMBA	MONTH	: JUNE	YEAR	: 2016
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018		

NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL							
1	Deepwell 1, Amaia Scapes Calamba	Source	6/29/2016	3:57 PM	3	ABSENCE	ABSENCE
2	Block 39 Lot 1, Amaia Scapes Calamba	Distribution	6/29/2016	4:11 PM	-	ABSENCE	ABSENCE
3	Deepwell 3, Amaia Scapes Calamba	Source	6/29/2016	4:22 PM	1	ABSENCE	ABSENCE
4	Guardhouse, Amaia Scapes Calamba	Distribution	6/29/2016	4:37 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		4	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES
TEST METHODS USED ⁴ : ¹ Pour Plate, ² Enzyme Substrate (Colilert®-18) REFERENCES : ³ Philippine National Standard for Drinking Water, 2007 ⁴ Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CERTIFIED CORRECT




CYRIL A. ERICA, RMT

AMPARO C. CAÑAMO

Analyst (License No. 0054161)

Head of Laboratory

DATE/TIME

DATE/TIME

7/7/2016 9:00 AM

7/11/2016 3:15 P.M.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : ALAMINOS	MONTH : JUNE	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES							
1	Water Tank, Bellavita Homes	Source	6/29/2016	2:07 PM	<1	ABSENCE	ABSENCE
2	Block 8 Lot 1, Phase 1, BellaVita Homes	Distribution	6/29/2016	2:04 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY



 CYRILLE A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

7/19/2016 9:00AM

CERTIFIED CORRECT



 AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

7/11/2016 3:22 p.m.

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY	: SANTA CRUZ	MONTH	: JUNE	YEAR	: 2016
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018		

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL							
1	Source after Filter, Laguna Sports Complex	Source	6/29/2016	12:21 PM	8	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	Distribution	6/29/2016	12:30 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY




CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

7/7/2016 9:00 Am

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

7/11/2016 3:12 PM.