

CITY/MUNICIPALITY : BIÑAN		MONTH : MAY	YEAR : 2016				
DOH ACCREDITATION NO : 04A-010-16-LW-2		VALIDITY : December 31, 2018					
NO	ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN							
1	Laguna Well Field 1	Source	5/26/2016	8:40 AM	<1	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	Source	5/10/2016	11:58 AM	3	ABSENCE	ABSENCE
3	Blk 3 Lot 28, Santol st., Phase 4C, San Jose Village I	Distribution	5/10/2016	12:34 PM	-	ABSENCE	ABSENCE
4	Pump 2, Jacana St., Phase 3B, San Jose Village I	Source	5/10/2016	11:33 AM	-	ABSENCE	ABSENCE
5	Blk 2 Lot 18, Jacana St., Phase 3B, San Jose Village I	Distribution	5/10/2016	11:46 AM	-	ABSENCE	ABSENCE
6	Pump 11, Phase 5, San Jose Village II	Source	5/10/2016	12:45 PM	-	ABSENCE	ABSENCE
7	Blk 1 Lot 23, Camia St., Phase 5, San Jose Village II	Distribution	5/10/2016	12:54 PM	250	ABSENCE	ABSENCE
8	Pump 7, Phase 6, San Jose Village III	Source	5/10/2016	12:04 PM	-	ABSENCE	ABSENCE
9	Clubhouse, Phase 6, San Jose Village III	Distribution	5/10/2016	12:09 PM	-	ABSENCE	ABSENCE
BRGY. CANLALAY							
10	#84 A. Bonifacio St.	Distribution	5/26/2016	2:07 PM	-	ABSENCE	ABSENCE
11	Golden City Canlalay Clubhouse	Distribution	5/25/2016	3:14 PM	<1	ABSENCE	ABSENCE
BRGY. DELA PAZ							
12	9028 WP GP Sta. Bernardina St. Kapitana Dela Paz	Source	5/25/2016	2:32 PM	<1	ABSENCE	ABSENCE
13	Barangay Hall	Distribution	5/26/2016	2:25 PM	-	ABSENCE	ABSENCE
BRGY. GANADO							
14	Drinking Fountain, Ganado Elementary School	Distribution	5/17/2016	9:39 AM	3	ABSENCE	ABSENCE
BRGY. HALANG							
15	9999 WP Metroville Complex	Source	5/25/2016	3:27 PM	6	ABSENCE	ABSENCE
16	Clubhouse, Metroville Complex	Distribution	5/25/2016	3:38 PM	-	ABSENCE	ABSENCE
BRGY. LANGKIWA							
17	Block 3 Lot 9 Phase 2, Southville Langkiwa	Source	5/26/2016	9:58 AM	33	ABSENCE	ABSENCE
18	Block 21 Lot 5, Phase 2, Southville Langkiwa	Distribution	5/26/2016	10:13 AM	-	ABSENCE	ABSENCE
19	Drinking Fountain, Langkiwa Elementary School	Distribution	5/26/2016	10:26 AM	<1	ABSENCE	ABSENCE
BRGY. LOMA							
20	Block 2 Lot 16, Phase 1, Laguna Bel-Air 3	Source	5/16/2016	3:29 PM	-	ABSENCE	ABSENCE
21	Hillcrest Road, Block 2, Laguna Bel-Air 3	Distribution	5/16/2016	3:37 PM	-	ABSENCE	ABSENCE
22	4NR Block 99, Phase 4, Laguna Bel-Air 3	Source	5/16/2016	2:51 PM	2	ABSENCE	ABSENCE
23	Brenna Model House, Phase 1, Laguna Bel-Air 3	Distribution	5/16/2016	3:00 PM	-	ABSENCE	ABSENCE
24	Block 50, Phase 2, Laguna Bel-Air 3	Source	5/16/2016	3:10 PM	<1	ABSENCE	ABSENCE
25	Block 61 Lot 20, Laguna Bel-Air 3	Distribution	5/16/2016	3:19 PM	-	ABSENCE	ABSENCE
26	Block 61 Lot 20, Laguna Bel-Air 3	Distribution	5/16/2016	3:19 PM	-	ABSENCE	ABSENCE
BRGY. MALAMIG							
27	Block 5 Lot 16	Distribution	5/26/2016	11:02 AM	<1	ABSENCE	ABSENCE
BRGY. MAMPLASAN							
28	Tank, Verdana Homes Subdivision	Source	5/26/2016	9:36 AM	120	ABSENCE	ABSENCE
29	Clubhouse, Verdana Homes Subdivision	Distribution	5/26/2016	9:16 AM	-	ABSENCE	ABSENCE
BRGY. POBLACION							
30	9018 WP Public Market 4024 Town Proper	Source	5/25/2016	2:18 PM	<1	ABSENCE	ABSENCE
BRGY. PLATERO							
31	Drinking Fountain, St. Michael School of Biñan	Distribution	5/25/2016	12:33 PM	-	ABSENCE	ABSENCE
32	Sea-oil, National Road	Distribution	5/25/2016	12:41 PM	2	ABSENCE	ABSENCE
BRGY. SAN ANTONIO							
33	9022 Water Pump (WP) Faraon Subdivision	Source	5/25/2016	1:48 PM	1	ABSENCE	ABSENCE

34	Block 5 Lot 12, Margarita Homes Subdivision	Distribution	5/25/2016	1:00 PM	-	ABSENCE	ABSENCE
35	Drinking Fountain 1, Faraon Elementary School	Distribution	5/25/2016	2:04 PM	470	ABSENCE	ABSENCE
BRGY. SAN VICENTE							
36	9001 GP San Vicente	Source	5/17/2016	11:36 AM	1	ABSENCE	ABSENCE
37	B8 L6, Bayabas St., Olivarez 7	Distribution	5/17/2016	11:24 AM	-	ABSENCE	ABSENCE
BRGY. SANTO TOMAS							
38	Phase 2, Adelina Complex III Subdivision	Source	5/17/2016	1:14 PM	-	ABSENCE	ABSENCE
39	Gate Entrance, Adelina Complex III Subdivision	Distribution	5/26/2016	2:25 PM	-	ABSENCE	ABSENCE
40	1 LT Water Pump, Phase 1B, Olivarez Homes South	Source	5/17/2016	2:06 PM	-	ABSENCE	ABSENCE
41	Block 1 Lot 26, Phase 3, Olivarez Homes South	Distribution	5/17/2016	1:56 PM	-	ABSENCE	ABSENCE
42	5555 Block 1, Phase 4, Olivarez Homes South	Source	5/17/2016	1:37 PM	<1	ABSENCE	ABSENCE
43	Block 2 ot 9, Phase 4, Olivarez Homes South	Distribution	5/17/2016	1:46 PM	-	ABSENCE	ABSENCE
44	Pump House, Kalibo St., South City Homes	Source	5/17/2016	10:55 AM	-	ABSENCE	ABSENCE
45	Block 76 Lot 6, Tangub St., Pragmatic	Distribution	5/17/2016	11:06 AM	-	ABSENCE	ABSENCE
46	South Plains II Subdivision	Source	5/17/2016	10:39 AM	2	ABSENCE	ABSENCE
47	Block 11 Lot 2, South Plains II Subdivision	Distribution	5/17/2016	10:31 AM	-	ABSENCE	ABSENCE
48	Pump, Amsterdam St., Phase 2, Town & Country	Source	5/17/2016	2:43 PM	-	ABSENCE	ABSENCE
49	Block 35 Lot 21, Town & Country	Distribution	5/17/2016	2:35 PM	-	ABSENCE	ABSENCE
50	Water Tank, Pennsylvania St, Town & Country	Source	5/17/2016	2:20 PM	-	ABSENCE	ABSENCE
51	Block 2 Lot 5, Town & Country	Distribution	5/17/2016	2:26 PM	-	ABSENCE	ABSENCE
BRGY. SORO - SORO							
52	9067 Soro-soro	Source	5/17/2016	12:36 PM	<1	ABSENCE	ABSENCE
53	#76 Soro-Soro	Distribution	5/17/2016	12:46 PM	-	ABSENCE	ABSENCE
BRGY. TUBIGAN							
54	#60 Forinda Compound	Distribution	5/17/2016	12:23 PM	4	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		54	2007 PNSDW LIMIT³	<500	ABSENCE	ABSENCE	

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

DATE/TIME

6-6-2016 / 12:09 PM

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

6/6/2016 / 12:15 PM

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA ROSA	MONTH : MAY	YEAR : 2016
DOH ACCREDIATION NO. : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

NO	ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO							
1	#1354 Facundo Compound	Distribution	5/18/2016	2:13 PM	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	Source	5/12/2016	9:49 AM	<1	ABSENCE	ABSENCE
3	Block 1 Lot 5, South Hampton	Distribution	5/23/2016	10:15 AM	-	ABSENCE	ABSENCE
4	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	Distribution	5/23/2016	10:43 AM	-	ABSENCE	ABSENCE
BRGY. CAINGIN							
5	9002 Block 53, Phase 4, Southville	Source	5/23/2016	1:27 PM	-	ABSENCE	ABSENCE
6	Block 52 Lot 23, Phase 1, Southville	Distribution	5/23/2016	1:33 PM	-	ABSENCE	ABSENCE
BRGY. DILA							
7	Phase 3E, Mabuhay Homes 2000	Source	5/18/2016	3:16 PM	-	ABSENCE	ABSENCE
8	Block 2 Lot 10, Mabuhay Homes 2000	Distribution	5/18/2016	3:37 PM	-	ABSENCE	ABSENCE
9	Block 12, Phase 2E, Mabuhay Homes 2000	Source	5/18/2016	3:53 PM	-	ABSENCE	ABSENCE
10	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	Distribution	5/18/2016	4:02 PM	-	ABSENCE	ABSENCE
11	Drinking Fountain, Dila Elementary School	Distribution	5/18/2016	4:17 PM	-	ABSENCE	ABSENCE
BRGY. DITA							
12	Block 24 Lot 2, New Santa Rosa Homes	Source	5/23/2016	12:49 PM	-	ABSENCE	ABSENCE
13	Block 19 Lot 11, New Santa Rosa Homes	Distribution	5/23/2016	12:58 PM	-	ABSENCE	ABSENCE
14	Block 4 Lot 32, San Lorenzo Royale	Source	5/12/2016	9:13 AM	3	ABSENCE	ABSENCE
15	Block 11 Lot 52, San Lorenzo Royale	Distribution	5/12/2016	9:08 AM	-	ABSENCE	ABSENCE
16	Water Tank, SolCar Ville Subdivision	Source	5/23/2016	11:36 AM	-	ABSENCE	ABSENCE
17	Front Gate, SolCar Ville Subdivision	Distribution	5/23/2016	11:51 AM	-	ABSENCE	ABSENCE
18	Water Tank, Villa Esmeralda	Source	5/12/2016	9:26 AM	<1	ABSENCE	ABSENCE
19	Alabaster St., Villa Esmeralda	Distribution	5/12/2016	9:21 AM	-	ABSENCE	ABSENCE
20	#1780 National Road	Distribution	5/26/2016	12:23 PM	-	ABSENCE	ABSENCE
BRGY. DON JOSE							
21	Block 7 Lot 62, Phase 3, Laguna Bel-Air	Source	5/16/2016	2:09 PM	<1	ABSENCE	ABSENCE
22	Science HighSchool, Phase 1, Laguna Bel-Air	Distribution	5/16/2016	2:20 PM	-	ABSENCE	ABSENCE
23	Block 34 Lot 14, Phase 1, Laguna Bel-Air	Source	5/16/2016	2:31 PM	2	ABSENCE	ABSENCE
24	#60 Cypress St., Phase 1, Laguna Bel-Air	Distribution	5/16/2016	2:42 PM	-	ABSENCE	ABSENCE
25	Clubhouse, Block 62, Laguna Bel-Air	Distribution	5/23/2016	9:56 AM	-	ABSENCE	ABSENCE
26	Water Pump, Block 71, Phase 4, Laguna Bel-Air	Source	5/16/2016	4:27 PM	13	ABSENCE	ABSENCE
27	Block 71 Lot 4, Phase 2, Laguna Bel-Air	Distribution	5/16/2016	4:33 PM	-	ABSENCE	ABSENCE
28	Block 108, Phase 5, Laguna Bel-Air	Source	5/16/2016	4:11 PM	3	ABSENCE	ABSENCE
29	Church, Block 108, Phase 2, Laguna Bel-Air	Distribution	5/16/2016	4:17 PM	-	ABSENCE	ABSENCE
30	1NR Block 43, Laguna Bel-Air IV	Source	5/16/2016	4:43 PM	9	ABSENCE	ABSENCE
31	Block 47 Lot 12 Laguna Bel-Air IV	Distribution	5/16/2016	4:56 PM	-	ABSENCE	ABSENCE
32	8001, Pump 1, Acacia St., Santa Rosa Village I	Source	5/10/2016	10:59 AM	<1	ABSENCE	ABSENCE
33	Clubhouse., Santa Rosa Village I	Distribution	5/10/2016	11:11 AM	-	ABSENCE	ABSENCE
34	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	Source	5/10/2016	10:08 AM	110	ABSENCE	ABSENCE
35	101 Elde France St., Phase 4A, Santa Rosa Village II	Distribution	5/10/2016	10:43 AM	-	ABSENCE	ABSENCE
36	Clubhouse, Santa Rosa Estates I	Distribution	5/10/2016	10:01 AM	10	ABSENCE	ABSENCE
37	Reservoir, Hacienda Sta. Elena	Distribution	5/26/2016	9:55 AM	<1	ABSENCE	ABSENCE
BRGY. KANLURAN							
38	Malusak Bakery, #621 Rizal Boulevard	Distribution	5/25/2016	10:24 AM	3	ABSENCE	ABSENCE
BRGY. MACABLING							

39	Block 4 Lot 3, Rosa Subdivision	Distribution	5/23/2016	2:18 PM	-	ABSENCE	ABSENCE
40	Deepwell, Buena Rosa 9 Subdivision	Source	5/17/2016	8:51 AM	2	ABSENCE	ABSENCE
41	Block 3 Lot 1, Phase 2, Buena Rosa 9 Subdivision	Distribution	5/17/2016	8:58 AM	42	ABSENCE	ABSENCE
42	Deepwell, Corinthian Subdivision	Source	5/17/2016	9:10 AM	-	ABSENCE	ABSENCE
43	Guardhouse, Corinthian Subdivision	Distribution	5/23/2016	2:30 PM	200	ABSENCE	ABSENCE
44	Deepwell, Rosemont Subdivision	Source	5/23/2016	2:46 PM	1	ABSENCE	ABSENCE
45	Block 4 Lot 7, Rosemont Subdivision	Distribution	5/17/2016	8:40 AM	15	ABSENCE	ABSENCE
BRGY. MALITLIT							
46	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	Source	5/12/2016	8:16 AM	-	ABSENCE	ABSENCE
47	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	Distribution	5/12/2016	8:22 AM	-	ABSENCE	ABSENCE
48	Main Road, Phase 2, Terra Fortuna	Source	5/12/2016	8:50 AM	-	ABSENCE	ABSENCE
49	Block 11 Lot 16, Terra Fortuna	Distribution	5/12/2016	8:55 AM	-	ABSENCE	ABSENCE
50	9999 W, Villa Las Casas	Source	5/12/2016	8:33 AM	-	ABSENCE	ABSENCE
51	Block 1 Lot 17, Villa Las Casas	Distribution	5/12/2016	8:40 AM	-	ABSENCE	ABSENCE
BRGY. MARKET AREA							
52	Source, Market Area	Source	5/25/2016	11:44 AM	-	ABSENCE	ABSENCE
53	Block 9 Lot 2, Terry Town West	Distribution	5/25/2016	11:04 AM	3	ABSENCE	ABSENCE
BRGY. POOC							
54	Deepwell, Alinsod	Source	5/18/2016	2:04 PM	-	ABSENCE	ABSENCE
55	9999 Water Pump, Phase 5, Southville	Source	5/18/2016	2:29 PM	-	ABSENCE	ABSENCE
56	Block 46 Lot 2, Phase 2, Southville	Distribution	5/18/2016	2:54 PM	-	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ							
57	Water Pump, Pulong Sta. Cruz	Source	5/12/2016	10:04 AM	-	ABSENCE	ABSENCE
58	Purok 5, Sitio Arattan	Distribution	5/12/2016	10:14 AM	-	ABSENCE	ABSENCE
59	Block 6 Lot 8, Buklod Diwa	Distribution	5/26/2016	10:15 AM	<1	ABSENCE	ABSENCE
BRGY. SINALHAN							
60	Source, Block 1 Lot 23, Bayshore I	Source	5/18/2016	9:19 AM	-	ABSENCE	ABSENCE
61	Block 9 Lot 14, Bristol Bay St., Bayshore II	Distribution	5/18/2016	8:56 AM	-	ABSENCE	ABSENCE
62	4026, Sinalhan Road, Purok 2	Source	5/25/2016	11:22 AM	-	ABSENCE	ABSENCE
63	Amoranto Compound, Phase 2, Sinalhan	Distribution	5/26/2016	1:38 PM	-	ABSENCE	ABSENCE
BRGY. STO. DOMINGO							
64	Laguna Water Head Office, One Evotech Bldg.	Distribution	5/12/2016	2:34 PM	-	ABSENCE	ABSENCE
65	Clubhouse Santa Rosa Estates II	Distribution	5/10/2016	10:22 AM	-	ABSENCE	ABSENCE
BRGY. TAGAPO							
66	Water Pump, Metrogate	Source	5/18/2016	8:56 AM	-	ABSENCE	ABSENCE
67	Water Pump, Rosewood	Source	5/18/2016	9:16 AM	-	ABSENCE	ABSENCE
68	Block 3 Lot 29, Rosewood	Distribution	5/18/2016	9:30 AM	-	ABSENCE	ABSENCE
69	Block 4 Lot 1, Phase 2, Rosewood II	Distribution	5/25/2016	12:13 AM	-	ABSENCE	ABSENCE
70	#31 JP Rizal Boulevard	Distribution	5/25/2016	12:23 PM	<1	ABSENCE	ABSENCE
71	Drinking Fountain, Front Gate, Central I Elem. Sch.	Distribution	5/25/2016	10:43 AM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		71	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT

AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

6-6-2016 / 2:09 PM

DATE/TIME

6/6/2016 / 2:20 PM

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

CITY/MUNICIPALITY : CABUYAO		MONTH : MAY		YEAR : 2016			
DOH ACCREDITATION NO : 04A-010-16-LW-2		VALIDITY : December 31, 2018					
NO	ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIGAA							
1	#253 Elsol Subdivision	Distribution	5/23/2016	12:15 PM	<1	ABSENCE	ABSENCE
BRGY. CASILE							
2	Matang Tubig Spring	Source	5/26/2016	9:32 AM	<1	ABSENCE	ABSENCE
BRGY. GULOD							
3	Block 12, Noah St., Celestine Ville	Source	5/11/2016	12:31 PM	-	ABSENCE	ABSENCE
4	Guardhouse, Celestine Ville Avenue, Celestine Ville	Distribution	5/11/2016	12:46 PM	-	ABSENCE	ABSENCE
BRGY. MAMATID							
5	Tank, Buena Rosario Subdivision	Source	5/23/2016	8:55 AM	-	ABSENCE	ABSENCE
6	Block 7 Lot 6, Buena Rosario Subdivision	Distribution	5/23/2016	9:10 AM	-	ABSENCE	ABSENCE
7	Block 101 Samar st., Phase 2, Mabuhay City	Source	5/11/2016	10:36 AM	50	ABSENCE	ABSENCE
8	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	Distribution	5/11/2016	10:48 AM	<1	ABSENCE	ABSENCE
9	Block 141, Carmona St., Phase 2, Mabuhay City	Source	5/11/2016	12:06 PM	180	ABSENCE	ABSENCE
10	Block 4 Lot 20, Phase 2, Mabuhay City	Distribution	5/11/2016	12:17 PM	<1	ABSENCE	ABSENCE
11	Block 198, Galacia St., Phase 2, Mabuhay City	Source	5/11/2016	11:03 AM	180	ABSENCE	ABSENCE
12	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	Distribution	5/11/2016	11:13 AM	-	ABSENCE	ABSENCE
13	Panganig St., Phase 3 Cluster, Mabuhay City	Source	5/16/2016	1:55 PM	17	ABSENCE	ABSENCE
14	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	Distribution	5/16/2016	2:04 PM	-	ABSENCE	ABSENCE
15	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	Source	5/16/2016	2:29 PM	<1	ABSENCE	ABSENCE
16	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	Distribution	5/16/2016	2:17 PM	-	ABSENCE	ABSENCE
17	Joshua St., Phase 5, Mabuhay City	Source	5/16/2016	1:31 PM	<1	ABSENCE	ABSENCE
18	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	Distribution	5/16/2016	1:37 PM	-	ABSENCE	ABSENCE
BRGY. MARINIG							
19	Block 3 Lot 17, Phase 1, Celestine Homes	Source	5/23/2016	9:42 AM	<1	ABSENCE	ABSENCE
20	Block 26, Lot 4, Phase 1, Celestine Homes	Distribution	5/23/2016	9:57 AM	<1	ABSENCE	ABSENCE
21	Block 9, Carnation St., Phase 2, Celestine Homes	Source	5/26/2016	11:31 AM	<1	ABSENCE	ABSENCE
22	Block 11 Lot 9, Phase 2, Celestine Homes	Distribution	5/23/2016	10:29 AM	<1	ABSENCE	ABSENCE
23	Block 25, Phase 3, Southville	Source	5/23/2016	11:05 AM	<1	ABSENCE	ABSENCE
24	Block 19 Lot 33, Phase 3, Southville	Distribution	5/23/2016	11:19 AM	30	ABSENCE	ABSENCE
BRGY. NIUGAN							
25	Water Pump, Niugan Elementary School Compound	Source	5/16/2016	4:14 PM	<1	ABSENCE	ABSENCE
26	Patricia's Apartment, St. Francis 7	Distribution	5/16/2016	4:23 PM	-	ABSENCE	ABSENCE
27	Block 45, Phase 8, Southville	Source	5/26/2016	10:49 AM	<1	ABSENCE	ABSENCE
28	Block 43 Lot 99, Southville	Distribution	5/26/2016	11:07 AM	6	ABSENCE	ABSENCE
29	Block 54, Phase 10, Southville	Source	5/16/2016	3:06 PM	<1	ABSENCE	ABSENCE
30	Block 43 Lot 99, Phase 10, Southville	Distribution	5/16/2016	3:16 PM	-	PRESENCE	ABSENCE
BRGY. PULO							
31	Block 12 Lot 22, Cabuyao Central	Source	5/16/2016	3:33 PM	2	ABSENCE	ABSENCE
32	Clubhouse, Narra Avenue, Cabuyao Central	Distribution	5/16/2016	3:38 PM	-	ABSENCE	ABSENCE
33	Block 11, Willow Park Homes	Source	5/16/2016	3:54 PM	-	ABSENCE	ABSENCE
34	Guardhouse, Main St., Willow Park Homes	Distribution	5/16/2016	4:01 PM	-	ABSENCE	ABSENCE
BRGY. SALA							
35	Guardhouse, Main St., Multiland III	Distribution	5/26/2016	11:53 AM	-	ABSENCE	ABSENCE
BRGY. SAN ISIDRO							
36	Source, Multiland IV	Source	5/31/2016	1:52 PM	<1	ABSENCE	ABSENCE

37	Block 3 Lot 33, Multiland IV	Distribution	5/26/2016	12:58 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		37	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

SANITARY CHECK PERFORMED							
1	Block 42 Lot 115, Phase 10, Southville	Distribution	5/31/2016	3:17 PM	-	PRESENCE	ABSENCE
2	Block 41 Lot 106, Phase 10, Southville	Distribution	5/31/2016	3:25 PM	-	PRESENCE	ABSENCE
3	Block 39 Lot 9, Phase 10, Southville	Distribution	5/31/2016	3:48 PM	-	PRESENCE	ABSENCE
NOTE: Distribution Rectification ON-GOING. Failure due to Malfunctioning Chlorinator Tank.							

NOTES	
TEST METHODS USED ⁴ : ¹ Pour Plate, ² Enzyme Substrate (Colilert®-18) REFERENCES : ³ Philippine National Standard for Drinking Water, 2007 : ⁴ Standard Methods for the Examination of Water and Waste Water, 22nd	

PREPARED BY



CYRIL A. ERICA, RMT
Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO
Head of Laboratory

DATE/TIME

6-6-2016 / 2:09 PM

DATE/TIME

6.6. 2016 / 2:30 PM.

LAGUNA AAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007



LAGUNA AAAWATER CORPORATION
 OPERATIONS DEPARTMENT
 LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CALAMBA	MONTH : MAY	YEAR : 2016
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL							
1	Deepwell 1, Amaia Scapes Calamba	Source	5/25/2016	5:05 PM	<1	ABSENCE	ABSENCE
2	Block 39 Lot 1, Amaia Scapes Calamba	Distribution	5/25/2016	6:05 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

6-6-2016/2:09 PM

CERTIFIED CORRECT

AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

6.6.2016 / 2:28 PM

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company
 G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sta. Domingo, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : ALAMINOS	MONTH : MAY	YEAR : 2016
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	


NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES							
1	Water Tank, Bellavita Homes	Source	5/25/2016	4:45 PM	<1	ABSENCE	ABSENCE
2	Block 8 Lot 1, Phase 1, BellaVita Homes	Distribution	5/25/2016	4:42 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES


TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CERTIFIED CORRECT



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

DATE/TIME

6-6-2016 / 2:09 PM

6-6-2016 / 2:26 PM

LAGUNA AAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007



LAGUNA AAAWATER CORPORATION
 OPERATIONS DEPARTMENT
 LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA CRUZ	MONTH : MAY	YEAR : 2016
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL							
1	Source after Filter, Laguna Sports Complex	Source	5/26/2016	1:17 PM	<1	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	Distribution	5/26/2016	3:06 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd

PREPARED BY

CERTIFIED CORRECT

CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

DATE/TIME

6-6-2016 / 2:09 PM

6-6-2016 / 2:29 PM

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007