

CITY/MUNICIPALITY : BIÑAN			MONTH : MAY			YEAR : 2017					
DOH ACCREDIATION NO : 04A-010-16-LW-2			VALIDITY : December 31, 2018			DOCUMENT NO : 17WQM-05-BIN					
NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
				***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup>	
				TOTAL	Escherichia coli						
<b>BRGY. BIÑAN</b>											
1	Laguna Well Field 1	S	16-May	0.56	-	0.02	6.95	-	10	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	S	2-May	0.43	-	0.02	7.06	-	-	ABSENCE	ABSENCE
3	Guardhouse Entrance, Phase 4C, San Jose Village I	D	2-May	0.40	-	0.02	6.39	-	< 1	ABSENCE	ABSENCE
4	Clubhouse, Phase 3B, San Jose Village I	D	2-May	0.40	-	0.02	6.93	-	< 1	ABSENCE	ABSENCE
5	Pump 11, Phase 5, San Jose Village II	S	2-May	< 0.20	-	0.02	7.00	-	-	ABSENCE	ABSENCE
6	Clubhouse, Phase 5, San Jose Village II	D	2-May	0.42	-	0.02	7.02	-	< 1	ABSENCE	ABSENCE
7	Pump 7, San Jose Village III	S	2-May	0.25	-	0.02	6.93	-	-	ABSENCE	ABSENCE
8	Clubhouse, Phase 6, San Jose Village III	D	2-May	0.84	-	0.02	6.87	-	59	ABSENCE	ABSENCE
<b>BRGY. CANLALAY</b>											
9	#124 A. Bonifacio St.	D	18-May	< 0.20	-	1.85	7.76	-	-	ABSENCE	ABSENCE
10	Golden City Canlalay Clubhouse	D	18-May	0.34	-	0.02	7.77	-	-	ABSENCE	ABSENCE
<b>BRGY. DELA PAZ</b>											
11	Almeda	S	18-May	0.73	-	0.02	7.78	-	-	ABSENCE	ABSENCE
12	Barangay Hall	D	18-May	0.77	-	0.02	7.82	-	-	ABSENCE	ABSENCE
<b>BRGY. HALANG</b>											
13	9999 WP Metroville Complex	S	18-May	0.96	< 2	0.02	7.43	**unobjectionable	-	ABSENCE	ABSENCE
14	Clubhouse, Metroville Complex	D	18-May	2.07	-	0.02	7.62	-	-	ABSENCE	ABSENCE
<b>BRGY. LANGKIWA</b>											
15	Block 33 Lot 22 Phase 2, Southville Langkiwa	D	16-May	0.50	-	0.02	6.8	-	-	ABSENCE	ABSENCE
16	Block 65 Lot 1 Phase 1, Southville Langkiwa	D	25-May	0.75	-	0.61	6.94	-	-	ABSENCE	ABSENCE
17	Block 20 Lot 7 Phase 3, Southville Langkiwa	D	16-May	0.46	-	0.14	7.08	-	9	ABSENCE	ABSENCE
18	Block 21 Lot 4 Phase 2, Southville Langkiwa	D	25-May	0.81	-	0.14	7.03	-	420	ABSENCE	ABSENCE
19	Block 18 Lot 11 Phase 4, Southville Langkiwa	D	16-May	0.45	-	0.02	7.27	-	-	ABSENCE	ABSENCE
20	Block 31 Lot 27, Phase 3, Southville Langkiwa	D	16-May	0.51	-	0.02	6.93	-	-	ABSENCE	ABSENCE
<b>BRGY. LOMA</b>											
21	Water Pump, Celina Mansion Subdivision	S	16-May	< 0.20	-	0.02	7.06	-	-	ABSENCE	ABSENCE
22	Block 2 Lot 6, Celina Mansion Subdivision	D	16-May	< 0.20	-	0.02	6.92	-	210	ABSENCE	ABSENCE

23	Water Pump, Block 4 Lot 37, Celina Technopark	S	16-May	< 0.20	-	0.02	7.03	-	-	ABSENCE	ABSENCE
24	Block 6 Lot 55, Celina Technopark	D	25-May	0.87	-	0.04	7.14	-	76	ABSENCE	ABSENCE
25	Block 8, Laguna Bel-Air 3	S	2-May	< 0.20	-	0.19	7.40	-	-	ABSENCE	ABSENCE
26	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	2-May	< 0.20	-	0.20	6.56	-	18	ABSENCE	ABSENCE
27	Block 2, Phase 4, Laguna Bel-Air 3	S	2-May	0.68	-	0.14	7.04	-	-	ABSENCE	ABSENCE
28	Hilcrest Road, Block 2, Laguna Bel-Air 3	D	2-May	0.67	-	0.20	7.19	-	< 1	ABSENCE	ABSENCE
29	Block 50, Phase 2, Laguna Bel-Air 3	S	2-May	< 0.20	-	7.30	0.12	-	-	ABSENCE	ABSENCE
30	Block 61 Lot 20, Laguna Bel-Air 3	D	2-May	< 0.20	-	7.32	0.30	-	240	ABSENCE	ABSENCE
<b>BRGY. MALAMIG</b>											
31	Block 5 Lot 16	D	16-May	0.49	-	0.02	6.98	-	27	ABSENCE	ABSENCE
<b>BRGY. MAMPLASAN</b>											
32	Tank, Verdana Homes Subdivision	S	16-May	< 0.20	-	0.02	7.09	-	140	ABSENCE	ABSENCE
33	Clubhouse, Verdana Homes Subdivision	D	16-May	< 0.20	-	0.02	7.27	-	-	ABSENCE	ABSENCE
34	United Laboratories (UNILAB) Inc.	D	17-May	< 0.20	-	0.02	6.89	-	< 1	ABSENCE	ABSENCE
<b>BRGY. POBLACION</b>											
35	Brgy. Health Center	S	18-May	< 0.20	-	1.41	7.81	-	-	ABSENCE	ABSENCE
<b>BRGY. PLATERO</b>											
36	Drinking Fountain, St. Michael School of Biñan	D	18-May	0.63	-	0.02	7.67	-	-	ABSENCE	ABSENCE
37	Sea-oil, National Road	D	18-May	0.69	-	0.02	7.28	-	-	ABSENCE	ABSENCE
<b>BRGY. SAN ANTONIO</b>											
38	Biñan City Hall	S	17-May	0.67	-	0.02	7.20	-	9	ABSENCE	ABSENCE
39	Arena Sports Complex	D	17-May	0.92	-	0.02	7.07	-	-	ABSENCE	ABSENCE
40	9022 Water Pump (WP) Faraon Subdivision	S	18-May	0.56	< 2	0.02	7.89	*unobjectionable	-	ABSENCE	ABSENCE
41	Brgy. Health Center, Faraon	D	18-May	0.61	-	0.02	7.82	-	-	ABSENCE	ABSENCE
42	Block 5 Lot 12, Margarita Homes Subdivision	D	18-May	< 0.20	-	0.20	7.52	-	-	ABSENCE	ABSENCE
43	Cistern Tank, Pavillion Mall	D	24-May	0.67	-	0.02	7.05	-	-	ABSENCE	ABSENCE
44	Jollibee, Pavillion Mall	D	25-May	0.63	-	0.02	7.83	-	-	ABSENCE	ABSENCE
<b>BRGY. SANTO NIÑO</b>											
45	Jollibee National Hi-Way	D	24-May	0.68	-	0.02	7.06	-	-	ABSENCE	ABSENCE
<b>BRGY. SAN VICENTE</b>											
46	407 San Vicente	S	9-May	< 0.20	-	0.02	7.63	-	-	ABSENCE	ABSENCE
47	B8 L6, Bayabas St., Olivarez 7	D	18-May	0.71	-	0.02	7.25	-	-	ABSENCE	ABSENCE
48	Biñan Doctors Hospital	D	18-May	0.76	-	0.02	7.36	-	-	ABSENCE	ABSENCE
<b>BRGY. SANTO TOMAS</b>											
49	Adelina	S	17-May	0.68	-	0.02	7.15	-	11	ABSENCE	ABSENCE
50	Gate Entrance, Adelina Complex III Subdivision	D	17-May	0.57	-	0.02	7.05	-	-	ABSENCE	ABSENCE
51	Block 1 Lot 26, Phase 3, Olivarez Homes South	D	9-May	0.82	-	0.02	7.52	-	-	ABSENCE	ABSENCE
52	Block 1 Lot 16, Phase 4, Olivarez Homes South	D	9-May	0.78	-	0.02	7.57	-	-	ABSENCE	ABSENCE
53	Pump House, Kalibo St., South City Homes	S	17-May	0.45	-	0.02	7.33	-	< 1	ABSENCE	ABSENCE
54	Block 76 Lot 6, Tangub St., Pragmatic	D	17-May	0.40	-	0.02	7.34	-	-	ABSENCE	ABSENCE

55	Block 2 Lot 1, South City Homes	D	17-May	0.49	-	0.02	7.26	-	-	ABSENCE	ABSENCE
56	Deepwell 3, Phase XI, South City Homes	S	17-May	0.23	-	0.02	7.24	-	6	ABSENCE	ABSENCE
57	Block 1 Lot 9, Phase XI, South City Homes	D	17-May	< 0.20	-	0.17	7.28	-	-	ABSENCE	ABSENCE
58	Pump, South Plains II Subdivision	S	17-May	0.57	-	0.02	7.37	-	5	ABSENCE	ABSENCE
59	Block 11 Lot 2, South Plains II Subdivision	D	25-May	0.49	-	0.02	7.69	-	-	ABSENCE	ABSENCE
60	Pump, Amsterdam St., Phase 2, Town & Country	S	9-May	0.61	-	0.02	7.56	-	-	ABSENCE	ABSENCE
61	Block 35 Lot 21, Town & Country	D	9-May	0.49	-	0.02	7.71	-	-	ABSENCE	ABSENCE
62	Sotuhville, Town & Country - Pennsylvania	S	9-May	2.35	-	0.02	7.53	-	-	ABSENCE	ABSENCE
63	Block 2 Lot 5, Town & Country	D	9-May	2.30	-	0.02	7.35	-	-	ABSENCE	ABSENCE
<b>BRGY. SORO - SORO</b>											
64	#76 Soro-Soro	D	18-May	0.70	-	0.02	7.73	-	-	ABSENCE	ABSENCE
<b>BRGY. TUBIGAN</b>											
65	#60 Florinda Compound	D	9-May	< 0.20	-	0.07	7.55	-	-	ABSENCE	ABSENCE
<b>BRGY. ZAPOTE</b>											
66	Water Pump, Althea	S	17-May	0.28	-	0.02	7.09	-	-	ABSENCE	ABSENCE
67	Clubhouse, Althea	D	17-May	< 0.20	-	0.36	7.40	-	27	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>67</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>


**REMARKS:** Samples analyzed as submitted


LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*-on-site testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU


METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Colilert®-18)

**ANALYZED BY:**

  
**ANNA KARLA S. GUTIERREZ**  
 Microbiologist  
 PRC License No. 0060968

  
**JOVEN M. MARAVILLA**  
 Chemist  
 PRC License No. 0012740

**CERTIFIED CORRECT:**

  
**CYRIL A. ERICA**  
 Laboratory Services Manager  
 PRC License No. 0054161

**LAGUNA AAAWATER CORPORATION**  
**OPERATIONS DEPARTMENT**  
**LABORATORY SERVICES**  
**SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA**

CITY/MUNICIPALITY : SANTA ROSA	MONTH : MAY	YEAR : 2017
DOH ACCREDITATION NO : D4A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-05-STR

NO	SAMPLE LOCATION			PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	DATE COLLECTED	***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup> TOTAL	Escherichia coli
<b>BRGY. BALIBAGO</b>											
1	#1354 Facundo Compound	D	23-May	0.56	-	0.15	6.88	-	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	S	3-May	1.69	< 2	0.02	7.76	*unobjectionable	-	ABSENCE	ABSENCE
3	Clubhouse, South Hampton	D	3-May	0.48	-	0.02	7.71	-	< 1	ABSENCE	ABSENCE
4	Block 5 Lot 19, JB Village, Sta. Rosa Tagaytay Road	D	25-May	< 0.20	-	0.02	7.46	-	-	ABSENCE	ABSENCE
5	Cistern Tank, Waltermart Sta. Rosa	D	25-May	0.92	-	1.83	7.63	-	5	ABSENCE	ABSENCE
6	Mang Inasal, Waltermart Sta. Rosa	D	24-May	< 0.20	-	0.63	7.71	-	98	ABSENCE	ABSENCE
<b>BRGY. CAINGIN</b>											
7	Block 57, Phase 1, Southville	S	18-May	0.80	< 2	0.02	7.52	**unobjectionable	-	ABSENCE	ABSENCE
8	Block 52 Lot 23, Phase 1, Southville	D	18-May	0.76	-	0.02	7.50	-	-	ABSENCE	ABSENCE
9	Block 29 Lot 45, Phase 2, Southville	D	23-May	0.69	-	0.02	7.57	-	-	ABSENCE	ABSENCE
<b>BRGY. DILA</b>											
10	Phase 3E, Mabuhay Homes 2000	S	18-May	< 0.20	< 2	0.02	7.36	*unobjectionable	-	ABSENCE	ABSENCE
11	Block 2 Lot 10, Mabuhay Homes 2000	D	18-May	< 0.20	-	0.02	7.31	-	-	ABSENCE	ABSENCE
12	Block 12, Phase 2E, Mabuhay Homes 2000	S	23-May	0.22	-	0.02	7.76	-	-	ABSENCE	ABSENCE
13	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	18-May	< 0.20	-	0.09	7.48	-	-	ABSENCE	ABSENCE
<b>BRGY. DITA</b>											
14	Block 24 Lot 2, New Santa Rosa Homes	S	18-May	0.45	-	0.02	7.73	-	-	ABSENCE	ABSENCE
15	Block 19 Lot 11, New Santa Rosa Homes	D	18-May	0.45	-	0.02	7.74	-	-	ABSENCE	ABSENCE
16	Block 4 Lot 32, San Lorenzo Royale	S	3-May	< 0.20	-	1.85	7.86	-	-	ABSENCE	ABSENCE
17	Block 11 Lot 52, San Lorenzo Royale	D	3-May	< 0.20	-	1.78	7.89	-	< 1	ABSENCE	ABSENCE
18	Water Tank, SolCar Ville Subdivision	S	18-May	0.76	< 2	0.02	7.37	**unobjectionable	-	ABSENCE	ABSENCE
19	Block 3 Lot 7, SolCar Ville Subdivision	D	18-May	0.61	-	0.02	7.52	-	-	ABSENCE	ABSENCE
20	Water Tank, Villa Esmeralda	S	3-May	0.30	-	1.36	7.87	-	-	ABSENCE	ABSENCE
21	Alabaster St., Villa Esmeralda	D	3-May	0.79	-	3.25	7.81	-	< 1	ABSENCE	ABSENCE
22	#1780 National Road	D	16-May	0.66	-	0.02	7.61	-	-	ABSENCE	ABSENCE
23	R & B Ice Plant, Inc.	D	24-May	0.66	-	0.02	7.36	-	< 1	ABSENCE	ABSENCE
<b>BRGY. DON JOSE</b>											
24	Block 7 Lot 62, Phase 3, Laguna Bel-Air	S	2-May	0.23	-	0.21	7.59	-	-	ABSENCE	ABSENCE
25	Science HighSchool, Phase 1, Laguna Bel-Air	D	2-May	0.27	-	0.17	7.58	-	< 1	ABSENCE	ABSENCE

26	Block 34 Lot 14, Phase 1, Laguna Bel-Air	S	2-May	0.97	-	0.02	7.52	-	-	ABSENCE	ABSENCE
27	Block 34 Lot 59, Phase 1, Laguna Bel-Air	D	2-May	0.95	-	0.02	7.56	-	< 1	ABSENCE	ABSENCE
28	Clubhouse, Block 62, Laguna Bel-Air	D	2-May	0.69	-	0.02	7.51	-	-	ABSENCE	ABSENCE
29	Water Pump, Block 71, Phase 4, Laguna Bel-Air	S	2-May	0.95	-	0.02	7.7	-	-	ABSENCE	ABSENCE
30	Block 71 Lot 4, Phase 2, Laguna Bel-Air	D	2-May	0.89	-	0.02	7.69	-	1	ABSENCE	ABSENCE
31	Block 108, Phase 5, Laguna Bel-Air	S	2-May	0.79	-	0.53	7.67	-	< 1	ABSENCE	ABSENCE
32	Church, Block 108, Phase 2, Laguna Bel-Air	D	2-May	0.78	-	0.45	7.59	-	-	ABSENCE	ABSENCE
33	1NR Block 43, Laguna Bel-Air IV	S	2-May	0.67	-	0.02	7.66	-	< 1	ABSENCE	ABSENCE
34	Block 47 Lot 22 Laguna Bel-Air IV	D	2-May	0.70	-	0.02	7.52	-	-	ABSENCE	ABSENCE
35	8001, Pump 1, Acacia St., Santa Rosa Village I	S	2-May	0.46	-	0.02	6.93	-	-	ABSENCE	ABSENCE
36	Clubhouse., Santa Rosa Village I	D	2-May	0.45	-	0.02	6.68	-	< 1	ABSENCE	ABSENCE
37	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	S	2-May	0.61	-	0.02	6.74	-	-	ABSENCE	ABSENCE
38	Clubhouse, Santa Rosa Village II	D	2-May	0.80	-	0.02	6.83	-	< 1	ABSENCE	ABSENCE
39	Clubhouse, Santa Rosa Estates I	D	2-May	0.76	-	0.02	6.84	-	< 1	ABSENCE	ABSENCE
40	Reservoir, Hacienda Sta. Elena	D	25-May	1.18	-	0.02	7.68	-	-	ABSENCE	ABSENCE
<b>BRGY. KANLURAN</b>											
41	#621 Rizal Boulevard	D	23-May	0.28	-	0.02	7.56	-	-	ABSENCE	ABSENCE
<b>BRGY. MACABLING</b>											
42	Deepwell, Buena Rosa 9 Subdivision	S	9-May	< 0.20	< 2	0.02	7.75	**unobjectionable	-	ABSENCE	ABSENCE
43	Block 3 Lot 11, Phase 2, Buena Rosa 9 Subdivision	D	9-May	< 0.20	-	0.02	7.60	-	150	ABSENCE	ABSENCE
44	Deepwell, Corinthian Subdivision	S	9-May	< 0.20	< 2	0.02	7.09	*unobjectionable	3	ABSENCE	ABSENCE
45	Gate Entrance, Corinthian Subdivision	D	3-May	< 0.20	-	0.02	7.15	-	-	ABSENCE	ABSENCE
46	Deepwell, Rosemont Subdivision	S	3-May	1.25	< 2	0.02	7.58	**unobjectionable	-	ABSENCE	ABSENCE
47	Block 9 Lot 8, Rosemont Subdivision	D	3-May	1.07	-	0.02	7.34	-	< 1	ABSENCE	ABSENCE
48	Water Pump, Metrogate	S	3-May	1.26	< 2	0.02	7.45	**unobjectionable	-	ABSENCE	ABSENCE
49	Clubhouse, Metrogate	D	3-May	1.40	-	0.02	7.55	-	< 1	ABSENCE	ABSENCE
<b>BRGY. MALITUT</b>											
50	Water Pump, Casan Residencia Subdivision	S	16-May	0.28	-	0.02	7.64	-	-	ABSENCE	ABSENCE
51	Block 1 Lot 1, Casan Residencia Subdivision	D	16-May	0.29	-	0.02	7.79	-	-	ABSENCE	ABSENCE
52	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	3-May	1.02	< 2	0.02	7.69	**unobjectionable	-	ABSENCE	ABSENCE
53	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	3-May	1.10	-	0.02	7.63	-	< 1	ABSENCE	ABSENCE
54	Main Road, Phase 2, Terra Fortuna	S	3-May	0.53	-	0.15	7.76	-	-	ABSENCE	ABSENCE
55	Block 11 Lot 16, Terra Fortuna	D	3-May	0.57	-	0.25	7.74	-	< 1	ABSENCE	ABSENCE
56	9999 W, Villa Las Casas	S	3-May	2.13	-	0.60	7.61	-	-	ABSENCE	ABSENCE
57	Block 1 Lot 17, Villa Las Casas	D	3-May	1.93	-	0.67	7.49	-	< 1	ABSENCE	ABSENCE
<b>BRGY. MARKET AREA</b>											
58	Source, Market Area	S	23-May	0.21	< 2	0.02	7.50	**unobjectionable	< 1	ABSENCE	ABSENCE
59	Block 9 Lot 2, Terry Town West	D	23-May	< 0.20	-	0.02	7.38	-	-	ABSENCE	ABSENCE
<b>BRGY. POOC</b>											
60	Deepwell, Alinsod	S	23-May	0.33	< 2	0.02	7.33	**unobjectionable	30	ABSENCE	ABSENCE
61	Tank, Villa Mercedes	S	18-May	< 0.20	< 2	0.02	7.33	**unobjectionable	-	ABSENCE	ABSENCE
62	Block 5 Lot 25, Villa Mercedes	D	18-May	< 0.20	-	0.02	7.34	-	-	ABSENCE	ABSENCE

BRGY. PULONG SANTA CRUZ											
63	Water Pump, Pulong Sta. Cruz	S	3-May	1.05	< 2	0.02	7.67	**unobjectionable	-	ABSENCE	ABSENCE
64	Block 7 Lot 3 Mercado Village, Pulong Sta. Cruz	D	3-May	0.98	-	0.02	7.70	-	< 1	ABSENCE	ABSENCE
65	Block 6 Lot 8, Buklod Diwa	D	25-May	0.47	-	0.02	7.90	-	-	ABSENCE	ABSENCE
BRGY. SINALHAN											
66	Block 5 Lot 7, Phase 1, Bayshore I	D	23-May	< 0.20	-	0.06	7.48	-	-	ABSENCE	ABSENCE
67	Block 6 Lot 10, Bayshore II	D	23-May	< 0.20	-	0.02	7.52	-	6	ABSENCE	ABSENCE
68	4026, Sinalhan Road, Purok 2	S	23-May	< 0.20	< 2	0.02	7.50	*unobjectionable	23	ABSENCE	ABSENCE
69	Amaranto Compound, Phase 2, Sinalhan	D	25-May	< 0.20	-	0.04	7.26	-	-	ABSENCE	ABSENCE
BRGY. SANTO DOMINGO											
70	Clubhouse Santa Rosa Estates II	D	2-May	0.90	-	0.15	6.88	-	-	ABSENCE	ABSENCE
BRGY. TAGAPO											
71	Water Pump, Fairfield of Margana Subdivision	S	9-May	< 0.20	-	0.02	7.18	-	-	ABSENCE	ABSENCE
72	Block 9 Lot 11, Fairfield of Margana Subdivision	D	9-May	< 0.20	-	0.22	7.15	-	150	ABSENCE	ABSENCE
73	Water Pump, Rosewood Homes I	S	3-May	< 0.20	< 2	0.02	7.50	*unobjectionable	-	ABSENCE	ABSENCE
74	Block 3 Lot 31, Rosewood Homes I	D	3-May	< 0.20	-	0.02	7.38	-	200	ABSENCE	ABSENCE
75	Block 4 Lot 1, Rosewood Homes II	D	3-May	< 0.20	-	0.02	7.40	-	-	ABSENCE	ABSENCE
76	#31 JP Rizal Boulevard	D	9-May	< 0.20	-	0.02	7.01	-	450	ABSENCE	ABSENCE
77	Water Pump, Buena Rosa 1 Subdivision	S	3-May	0.82	-	0.02	7.30	-	< 1	ABSENCE	ABSENCE
78	Block 4 Lot 9, Buena Rosa 1 Subdivision	D	3-May	< 0.20	-	0.02	7.64	-	-	ABSENCE	ABSENCE
79	Block 1 Lot 64, Buena Rosa 10 Subdivision	D	3-May	0.64	-	0.02	7.23	-	< 1	ABSENCE	ABSENCE
80	Cistern Tank, SM Sta. Rosa	D	25-May	0.92	-	1.83	7.63	-	< 1	ABSENCE	ABSENCE
81	Dairy Queen, SM Sta. Rosa	D	24-May	0.41	-	0.02	7.60	-	1	ABSENCE	ABSENCE
82	Cistern Tank, Robinson's Mall	D	24-May	0.23	-	0.02	7.43	-	6	ABSENCE	ABSENCE
83	Chummie Shawarma, Robinson's Mall	D	24-May	< 0.20	-	0.02	7.62	-	56	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>83</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>


REMARKS: Samples analyzed as submitted


LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, MPC - Heterotrophic Plate Count, \*\*\*-on-site testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/l, Color = 2.5 ACU, Turbidity = 0.02 NTU


METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Colilert®-18)

ANALYZED BY:

  
**ANNA KARLA S. GUTIERREZ**  
 Microbiologist  
 PRC License No. 0060968

  
**JOVEN M. MARAVILLA**  
 Chemist  
 PRC License No. 0012740

CERTIFIED CORRECT:

  
**CYRIL A. ERICA**  
 Laboratory Services Manager  
 PRC License No. 0054161

Page 3 of 3

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

LAGUNA AAAWATER CORPORATION  
OPERATIONS DEPARTMENT  
LABORATORY SERVICES  
**SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA**

CITY/MUNICIPALITY : CABUYAO	MONTH : MAY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-05-CAB

NO	SAMPLE LOCATION			PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	DATE COLLECTED	***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/ml	Coliforms/100 mL <sup>7</sup> TOTAL	Escherichia coli
<b>BRGY. BANAY-BANAY</b>											
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	24-May	1.25	< 2	0.02	7.27	**unobjectionable	3	ABSENCE	ABSENCE
2	Block 18 Lot 10, Lakeside Nest Subdivision	D	24-May	1.11	-	0.02	7.18	-	-	ABSENCE	ABSENCE
<b>BRGY. BANLIC</b>											
3	Water Pump, Gran Seville Subdivision	S	16-May	< 0.20	-	0.02	7.96	-	-	ABSENCE	ABSENCE
4	Guardhouse, Gran Seville Subdivision	D	16-May	< 0.20	-	0.02	7.91	-	< 1	ABSENCE	ABSENCE
<b>BRGY. BIGAA</b>											
5	#253 Elsol Subdivision	D	24-May	0.65	-	0.02	7.29	-	-	ABSENCE	ABSENCE
<b>BRGY. CASILE</b>											
6	Matang Tubig Spring	S	25-May	1.13	-	0.02	7.57	-	-	ABSENCE	ABSENCE
<b>BRGY. GULOD</b>											
7	Block 12, Noah St., Celestine Ville	S	9-May	1.22	< 2	0.02	7.56	**unobjectionable	-	ABSENCE	ABSENCE
8	Block 11 Lot 4, Celestine Ville	D	9-May	1.11	-	0.02	7.44	-	-	ABSENCE	ABSENCE
<b>BRGY. MAMATID</b>											
9	Tank, Buena Rosario Subdivision	S	9-May	< 0.20	-	0.02	7.09	-	-	ABSENCE	ABSENCE
10	Block 7 Lot 6, Buena Rosario Subdivision	D	9-May	< 0.20	-	0.62	7.42	-	-	ABSENCE	ABSENCE
11	Block 101 Samar st., Phase 1, Mabuhay City	S	9-May	0.26	-	0.05	7.34	-	-	ABSENCE	ABSENCE
12	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	24-May	< 0.20	-	0.02	7.09	-	8	ABSENCE	ABSENCE
13	Block 141, Carmona St., Phase 2, Mabuhay City	S	9-May	< 0.20	-	0.02	7.55	-	11	ABSENCE	ABSENCE
14	Block 134 Lot 22, Phase 2, Mabuhay City	D	9-May	< 0.20	-	0.02	7.58	-	-	ABSENCE	ABSENCE
15	Block 198, Galacia St., Phase 2, Mabuhay City	S	24-May	< 0.20	-	0.10	7.10	-	-	ABSENCE	ABSENCE
16	Block 182 Lot 2, Mabuhay Ave, Phase 2, Mabuhay	D	9-May	< 0.20	-	0.02	7.56	-	-	ABSENCE	ABSENCE
17	Panganig St., Phase 3 Cluster, Mabuhay City	S	9-May	0.23	< 2	0.02	7.53	*unobjectionable	-	ABSENCE	ABSENCE
18	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	9-May	0.30	-	0.02	7.50	-	< 1	ABSENCE	ABSENCE
19	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	9-May	0.40	< 2	0.02	7.29	*unobjectionable	-	ABSENCE	ABSENCE
20	Block 34 Lot 36, Malang St., Phase 3 Luxury,	D	9-May	0.22	-	0.02	7.46	-	< 1	ABSENCE	ABSENCE
21	Joshua St., Phase 5, Mabuhay City	S	24-May	0.35	-	0.02	7.37	-	26	ABSENCE	ABSENCE
22	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	24-May	< 0.20	-	0.02	7.37	-	-	ABSENCE	ABSENCE

23	Source, Phase 1E Mabuhay Executive	S	9-May	0.21	< 2	0.02	7.29	*unobjectionable	-	ABSENCE	ABSENCE
24	Block 23G Lot 9, Phase 1E Mabuhay Executive	D	24-May	0.43	-	0.43	7.09	-	-	ABSENCE	ABSENCE
<b>BRGY. MARINIG</b>											
25	Block 3 Lot 17, Phase 1, Celestine Homes	S	24-May	0.23	< 2	0.02	7.51	**unobjectionable	< 1	ABSENCE	ABSENCE
26	Block 23, Lot 10, Phase 1, Celestine Homes	D	24-May	0.47	-	0.10	7.53	-	-	ABSENCE	ABSENCE
27	Block 9, Carnation St., Phase 2, Celestine Homes	S	24-May	< 0.20	-	0.02	7.65	**unobjectionable	< 1	ABSENCE	ABSENCE
28	Block 11 Lot 19, Phase 2, Celestine Homes	D	24-May	< 0.20	-	0.02	7.71	-	-	ABSENCE	ABSENCE
29	Block 25, Phase 3, Southville	S	24-May	0.40	< 2	0.02	7.29	**unobjectionable	2	ABSENCE	ABSENCE
30	Block 19 Lot 33, Phase 3, Southville	D	24-May	0.51	-	0.06	7.37	-	-	ABSENCE	ABSENCE
<b>BRGY. NIUGAN</b>											
31	Water Pump, Niugan Elementary School Compound	S	16-May	< 0.20	-	0.04	7.96	-	-	ABSENCE	ABSENCE
32	Block 6 Lot 2, St. Francis Homes 6	D	24-May	< 0.20	-	0.05	7.31	-	380	ABSENCE	ABSENCE
33	Block 45, Phase 8, Southville	S	24-May	0.93	< 2	0.02	7.38	**unobjectionable	-	ABSENCE	ABSENCE
34	Block 40 Lot 132, Southville	D	24-May	1.05	-	0.02	7.38	-	-	ABSENCE	ABSENCE
35	Block 54, Phase 10, Southville	S	24-May	0.62	< 2	0.02	7.10	**unobjectionable	-	ABSENCE	ABSENCE
36	Block 48 Lot 108, Phase 10, Southville	D	24-May	0.70	-	0.02	7.14	-	-	ABSENCE	ABSENCE
<b>BRGY. PULO</b>											
37	Water Pump, Block 12 Lot 22, Cabuyao Central	S	16-May	0.86	-	0.26	7.92	-	-	ABSENCE	ABSENCE
38	Clubhouse, Narra Avenue, Cabuyao Central	D	16-May	1.06	-	7.81	7.82	-	1	ABSENCE	ABSENCE
39	Water Pump, Block 11, Willow Park Homes	S	16-May	0.98	< 2	0.02	7.88	**unobjectionable	-	ABSENCE	ABSENCE
40	Clubhouse, Willow Park Homes	D	16-May	0.97	-	0.02	7.69	-	< 1	ABSENCE	ABSENCE
<b>BRGY. SALA</b>											
41	Guardhouse, Main St., Multiland III	D	25-May	0.39	-	0.20	7.38	-	-	ABSENCE	ABSENCE
<b>BRGY. SAN ISIDRO</b>											
42	Source, Multiland IV	S	24-May	< 0.20	-	0.02	7.12	-	-	ABSENCE	ABSENCE
43	Block 3 Lot 33, Multiland IV	D	16-May	< 0.20	-	0.44	7.87	-	2	ABSENCE	ABSENCE
44	Water Pump, San Isidro Heights Subdivision	S	16-May	0.27	-	0.02	7.87	-	-	ABSENCE	ABSENCE
45	Block 3 Lot 2, San Isidro Heights Subdivision	D	16-May	0.20	-	0.17	7.85	-	76	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>45</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>


REMARKS: Samples analyzed as submitted


LEGEND: ACU - Apparent Color (Unit), NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*-on-site testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU


METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Colilert®-18)

ANALYZED BY:

  
ANNA KARLA S. GUTIERREZ  
Microbiologist  
PRC License No. 0060968

  
JOVEN M. MARAVILLA  
Chemist  
PRC License No. 0012740

CERTIFIED CORRECT:

  
CYRIL A. ERICA  
Laboratory Services Manager  
PRC License No. 0054161

Page 2 of 2

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

Laguna AAWater Corporation | Q1F One Ecolan Bldg., Nuvall Sts., Rizal City, Laguna | +63 49 544-4386 • +63 2 519-4429



CITY/MUNICIPALITY	: CALAMBA	MONTH	: MAY	YEAR	: 2017
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018	DOCUMENT NO	: 17WQM-05-CAL

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY			
	ADDRESS	TYPE		***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup> TOTAL	Escherichia coli	
<b>BRGY. BARANDAL</b>												
1	Deepwell 1, Amaia Scapes Calamba	S	22-May	0.70	-	0.02	7.87	-	-	ABSENCE	ABSENCE	
2	Block 1 Lot 2, Amaia Scapes Calamba	D	22-May	0.34	-	0.02	7.71	-	-	ABSENCE	ABSENCE	
3	Deepwell 2, Amaia Scapes Calamba	S	22-May	0.52	-	0.02	7.82	-	-	ABSENCE	ABSENCE	
4	Block 39 Lot 5, Amaia Scapes Calamba	D	22-May	0.64	-	0.02	7.85	-	-	ABSENCE	ABSENCE	
<b>BRGY. PUTING LUPA</b>												
5	Phase 1, Greenfields	D	22-May	0.40	-	0.02	7.84	-	-	ABSENCE	ABSENCE	
6	Block 11, Kanlaon St., Greenfields	D	22-May	0.40	-	0.02	7.80	-	-	ABSENCE	ABSENCE	
7	Clubhouse, Greenfields	D	22-May	< 0.20	-	0.02	7.82	-	-	ABSENCE	ABSENCE	
<b>TOTAL SAMPLES ANALYZED</b>			<b>7</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*-onsite testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution


DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Collert®-18)

ANALYZED BY:

CERTIFIED CORRECT:

  
ANNA MARIA S. GUTIERREZ  
Microbiologist  
PRC License No. 0060958

  
JOVEN M. MARAVILLA  
Chemist  
PRC License No. 0012740

  
CYRIL A. ERICA  
Laboratory Services Manager  
PRC License No. 0054161

Page 1 of 1

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

LAGUNA AAAWATER CORPORATION  
OPERATIONS DEPARTMENT  
LABORATORY SERVICES  
**SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA**

CITY/MUNICIPALITY : ALAMINOS	MONTH : MAY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-05-ALA

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY			
	ADDRESS	TYPE		***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup>		
		TOTAL	Escherichia coli									
BRGY. SAN ANDRES												
1	Water Tank, Bellavita Homes	S	22-May	0.27	< 2	0.19	7.78	**unobjectionable	-	ABSENCE	ABSENCE	
2	Block 8 Lot 1, Phase 1, BellaVita Homes	D	22-May	0.25	-	0.08	7.49	-	-	ABSENCE	ABSENCE	
<b>TOTAL SAMPLES ANALYZED</b>		<b>2</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>	

REMARKS: Samples analyzed as submitted


LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*- onsite testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Coli-18)

ANALYZED BY:

  
ANNA KARLA S. GUTIERREZ  
Microbiologist  
PRC License No. 0060968

  
JOVEN M. MARAVILLA  
Chemist  
PRC License No. 0012740

CERTIFIED CORRECT:

  
CYRIL A. ERICA  
Laboratory Services Manager  
PRC License No. 0054161

CITY/MUNICIPALITY	: SANTA CRUZ	MONTH	: MAY	YEAR	: 2017
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018	DOCUMENT NO	: 17WQM-05-STC

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY			
NO	ADDRESS	TYPE		***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup> TOTAL	Escherichia coli	
<b>BRGY. BUBUKAL</b>												
1	Source after Filter, Laguna Sports Complex	S	22-May	1.04	< 2	0.02	8.05	*unobjectionable	-	ABSENCE	ABSENCE	
2	Canteen No. 4 in front of Laguna University	D	22-May	0.79	-	0.02	7.69	-	-	ABSENCE	ABSENCE	
<b>TOTAL SAMPLES ANALYZED</b>			<b>2</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*-arsite testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution


DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU


METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Colitag<sup>®</sup>-18)

ANALYZED BY:

CERTIFIED CORRECT:

  
ANNA KARLA S. GUTIERREZ  
Microbiologist  
PRC License No. 0060968

  
JOVEN M. MARAVILLA  
Chemist  
PRC License No. 0012740

  
CYRIL A. BRICA  
Laboratory Services Manager  
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION  
OPERATIONS DEPARTMENT  
LABORATORY SERVICES  
**SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA**

<b>CITY/MUNICIPALITY</b> : PAGSANJAN			<b>MONTH</b> : MAY			<b>YEAR</b> : 2017					
<b>DOH ACCREDITATION NO</b> : 04A-010-16-LW-2			<b>VALIDITY</b> : December 31, 2018			<b>DOCUMENT NO</b> : 17WQM-05-PAG					
SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine <sup>1</sup> mg/L	Color <sup>2</sup> ACU	Turbidity <sup>3</sup> NTU	pH <sup>4</sup>	Taste/Odor <sup>5</sup>	HPC <sup>6</sup> CFU/mL	Coliforms/100 mL <sup>7</sup> TOTAL <i>Escherichia coli</i>	
<b>BRGY. SABANG</b>											
1	Purok 6, Moresco Ville 2	S	22-May	0.75	< 2	0.02	7.73	*unobjectionable	-	ABSENCE	ABSENCE
2	Reservoir, Moresco Ville 2	S	22-May	0.72	-	0.02	7.60	-	-	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>2</b>	<b>PNSDW LIMIT</b>	<b>0.30 - 1.50</b>	<b>10 (max)</b>	<b>5 (max)</b>	<b>6.5 - 8.5</b>	<b>unobjectionable</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted


LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, \*\*\*-onsite testing, \* - unobjectionable - slightly chlorinous, \*\* - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: <sup>1</sup>DPD Colorimetric, <sup>2</sup>Visual Comparison-Platinum/Cobalt, <sup>3</sup>Nephelometric, <sup>4</sup>Electrometric, <sup>5</sup>Sensory, <sup>6</sup>Pour Plate, <sup>7</sup>Enzyme Substrate (Colilert®-18)

**ANALYZED BY:**

  
ANNA KARLA S. GUTIERREZ  
Microbiologist  
PRC License No. 0060968

  
JOVEN M. MARAVILLA  
Chemist  
PRC License No. 0012740

**CERTIFIED CORRECT:**

  
CYRIL A. ERICA  
Laboratory Services Manager  
PRC License No. 0054161